

November 16, 2016

Ocean Township School District
Waretown Elementary School
64 Railroad Avenue
Waretown, NJ 08758

Dear Waretown Elementary School Community,

Our school system is committed to protecting student, teacher, and staff health. To protect our community and be in compliance with the Department of Education regulations, Ocean Township School District tested our schools' drinking water for lead.

In accordance with the Department of Education regulations, Waretown Elementary will implement immediate remedial measures for any drinking water outlet with a result greater than the action level of 15 µg/l (parts per billion [ppb]). This includes turning off the outlet unless it is determined the location must remain on for non-drinking purposes. In these cases, a "DO NOT DRINK – SAFE FOR HANDWASHING ONLY" sign will be posted.

Results of our Testing

Following instructions given in technical guidance developed by the New Jersey Department of Environmental Protection, we completed a plumbing profile for each of the buildings within Ocean Township School District. Through this effort, we identified and tested all drinking water and food preparation outlets. Of the 63 samples taken, all but 3 tested below the lead action level established by the US Environmental Protection Agency for lead in drinking water (15 µg/l [ppb]).

The table below identifies the drinking water outlets that tested above the 15 µg/l for lead, the actual lead level, and what temporary remedial action Ocean Township School District has taken to reduce the levels of lead at these locations.

| Location | First Draw Result in µg/l (ppb) | Remedial Action |
|--|--|---|
| Boiler Room Service Line Outlet ID # MM-1F-DW-01 | 33.2 | Non-Drinking Source Disconnected |
| 2 Cooking Vats in the Kitchen | 18.0 41.1 | Disconnected outlet and bottled water provided for food preparation. Posted signage "DO NOT DRINK- SAFE FOR HANDWASHING ONLY" |
| | | |
| | | |

Health Effects of Lead

High levels of lead in drinking water can cause health problems. Lead is most dangerous for pregnant women, infants, and children under 6 years of age. It can cause damage to the brain and kidneys, and can interfere with the production of red blood cells that carry oxygen to all parts of your body. Exposure to high levels of lead during pregnancy contributes to low birth weight and developmental delays in infants. In young children, lead exposure can lower IQ levels, affect hearing, reduce attention span, and hurt school performance. At *very* high levels, lead can even cause brain damage. Adults with kidney problems and high blood pressure can be affected by low levels of lead more than healthy adults.

How Lead Enters our Water

Lead is unusual among drinking water contaminants in that it seldom occurs naturally in water supplies like groundwater, rivers and lakes. Lead enters drinking water primarily as a result of the corrosion, or wearing away, of materials containing lead in the water distribution system and in building plumbing. These materials include lead-based solder used to join copper pipe, brass, and chrome-plated brass faucets. In 1986, Congress banned the use of lead solder containing greater than 0.2% lead, and restricted the lead content of faucets, pipes and other plumbing materials. However, even the lead in plumbing materials meeting these new requirements is subject to corrosion. When water stands in lead pipes or plumbing systems containing lead for several hours or more, the lead may dissolve into the drinking water. This means the first water drawn from the tap in the morning *may* contain fairly high levels of lead.

Lead in Drinking Water

Lead in drinking water, although rarely the sole cause of lead poisoning can significantly increase a person's total lead exposure, particularly the exposure of children under the age of 6. EPA estimates that drinking water can make up 20% or more of a person's total exposure to lead.

For More Information

A copy of the test results is available in our central office for inspection by the public, including students, teachers, other school personnel, and parents, and can be viewed between the hours of 8:30 a.m. and 3:00 p.m. and are also available on our website at www.otsdk6.org. For more information about water quality in our schools, contact Dr. Christopher Lommerin at the Superintendent Office, 609-693-3131 x130.

For more information on reducing lead exposure around your home and the health effects of lead, visit EPA's Web site at www.epa.gov/lead, call the National Lead Information Center at 800-424-LEAD, or contact your health care provider.

If you are concerned about lead exposure at this facility or in your home, you may want to ask your health care providers about testing children to determine levels of lead in their blood.

Sincerely,

Christopher Lommerin
Superintendent of Schools



Results Report

Order ID: 6112158

Karl Environmental Group
20 Lauck Road
Mohnton, PA 19540

Project: PA/NJ Lead & Copper 2016

Attn: Kristian Bills

Regulatory ID:

| | | |
|---------------------------|-----------------------------------|---------------------------------------|
| Sample Number: 6112158-01 | Site: OTW-BLANK | Sample ID: Waretown Elementary School |
| Collector: DT | Collect Date: 11/07/2016 11:20 pm | Sample Type: S |

| Department / Test / Parameter | Result | Units | Method | R.L. | DF | Prep Date | By | Analysis Date | By |
|-------------------------------|--------|-------|--------|------|----|-----------|----|---------------|----|
|-------------------------------|--------|-------|--------|------|----|-----------|----|---------------|----|

Metals

| | | | | | | | | | |
|------|--------|------|-----------|------|---|----------|-----|----------------|-----|
| Lead | < 1.00 | µg/L | EPA 200.8 | 1.00 | 1 | 11/09/16 | RPV | 11/14/16 13:50 | RPV |
|------|--------|------|-----------|------|---|----------|-----|----------------|-----|

| | | |
|---------------------------|-----------------------------------|---------------------------------------|
| Sample Number: 6112158-02 | Site: OTW-SL-1FL-BOILER | Sample ID: Waretown Elementary School |
| Collector: DT | Collect Date: 11/07/2016 11:22 pm | Sample Type: S |

| Department / Test / Parameter | Result | Units | Method | R.L. | DF | Prep Date | By | Analysis Date | By |
|-------------------------------|--------|-------|--------|------|----|-----------|----|---------------|----|
|-------------------------------|--------|-------|--------|------|----|-----------|----|---------------|----|

Metals

| | | | | | | | | | |
|------|------|------|-----------|------|---|----------|-----|----------------|-----|
| Lead | 33.2 | µg/L | EPA 200.8 | 1.00 | 1 | 11/09/16 | RPV | 11/14/16 13:59 | RPV |
|------|------|------|-----------|------|---|----------|-----|----------------|-----|

| | | |
|---------------------------|-----------------------------------|---------------------------------------|
| Sample Number: 6112158-03 | Site: OTW-KC-1FL-KITCHEN-1 | Sample ID: Waretown Elementary School |
| Collector: DT | Collect Date: 11/07/2016 11:44 pm | Sample Type: S |

| Department / Test / Parameter | Result | Units | Method | R.L. | DF | Prep Date | By | Analysis Date | By |
|-------------------------------|--------|-------|--------|------|----|-----------|----|---------------|----|
|-------------------------------|--------|-------|--------|------|----|-----------|----|---------------|----|

Metals

| | | | | | | | | | |
|------|------|------|-----------|------|---|----------|-----|----------------|-----|
| Lead | 5.07 | µg/L | EPA 200.8 | 1.00 | 1 | 11/09/16 | RPV | 11/14/16 14:01 | RPV |
|------|------|------|-----------|------|---|----------|-----|----------------|-----|

| | | |
|---------------------------|-----------------------------------|---------------------------------------|
| Sample Number: 6112158-04 | Site: OTW-KC-1FL-KITCHEN-2 | Sample ID: Waretown Elementary School |
| Collector: DT | Collect Date: 11/07/2016 11:55 pm | Sample Type: S |

| Department / Test / Parameter | Result | Units | Method | R.L. | DF | Prep Date | By | Analysis Date | By |
|-------------------------------|--------|-------|--------|------|----|-----------|----|---------------|----|
|-------------------------------|--------|-------|--------|------|----|-----------|----|---------------|----|

Metals

| | | | | | | | | | |
|------|------|------|-----------|------|---|----------|-----|----------------|-----|
| Lead | 1.00 | µg/L | EPA 200.8 | 1.00 | 1 | 11/09/16 | RPV | 11/14/16 14:03 | RPV |
|------|------|------|-----------|------|---|----------|-----|----------------|-----|

| | | |
|---------------------------|-----------------------------------|---------------------------------------|
| Sample Number: 6112158-05 | Site: OTW-KC-1FL-KITCHEN-3 | Sample ID: Waretown Elementary School |
| Collector: DT | Collect Date: 11/07/2016 11:53 pm | Sample Type: S |

| Department / Test / Parameter | Result | Units | Method | R.L. | DF | Prep Date | By | Analysis Date | By |
|-------------------------------|--------|-------|--------|------|----|-----------|----|---------------|----|
|-------------------------------|--------|-------|--------|------|----|-----------|----|---------------|----|

Metals

| | | | | | | | | | |
|------|------|------|-----------|------|---|----------|-----|----------------|-----|
| Lead | 2.48 | µg/L | EPA 200.8 | 1.00 | 1 | 11/09/16 | RPV | 11/14/16 14:05 | RPV |
|------|------|------|-----------|------|---|----------|-----|----------------|-----|

Report Generated On: 11/15/2016 5:00 pm 6112158
 STL_Results Revision #1.6 Effective: 07/09/2014





SUBURBAN TESTING LABS

Sample Number: 6112158-06 Site: OTW-KC-1FL-KITCHEN-4 Sample ID: Waretown Elementary School
 Collector: DT Collect Date: 11/07/2016 11:58 pm Sample Type: S

| Department / Test / Parameter | Result | Units | Method | R.L. | DF | Prep Date | By | Analysis Date | By |
|-------------------------------|--------|-------|--------|------|----|-----------|----|---------------|----|
|-------------------------------|--------|-------|--------|------|----|-----------|----|---------------|----|

Metals

Lead 1.94 µg/L EPA 200.8 1.00 1 11/09/16 RPV 11/14/16 14:07 RPV

Sample Number: 6112158-07 Site: OTW-KC-1FL-KITCHEN-5 Sample ID: Waretown Elementary School
 Collector: DT Collect Date: 11/08/2016 12:04 am Sample Type: S

| Department / Test / Parameter | Result | Units | Method | R.L. | DF | Prep Date | By | Analysis Date | By |
|-------------------------------|--------|-------|--------|------|----|-----------|----|---------------|----|
|-------------------------------|--------|-------|--------|------|----|-----------|----|---------------|----|

Metals

Lead 5.08 µg/L EPA 200.8 1.00 1 11/09/16 RPV 11/14/16 14:11 RPV

Sample Number: 6112158-08 Site: OTW-CV-1FL-KITCHEN-6 Sample ID: Waretown Elementary School
 Collector: DT Collect Date: 11/08/2016 12:00 am Sample Type: S

| Department / Test / Parameter | Result | Units | Method | R.L. | DF | Prep Date | By | Analysis Date | By |
|-------------------------------|--------|-------|--------|------|----|-----------|----|---------------|----|
|-------------------------------|--------|-------|--------|------|----|-----------|----|---------------|----|

Metals

Lead 18.0 µg/L EPA 200.8 1.00 1 11/09/16 RPV 11/14/16 14:13 RPV

Sample Number: 6112158-10 Site: OTW-CV-1FL-KITCHEN-7 Sample ID: Waretown Elementary School
 Collector: DT Collect Date: 11/08/2016 2:02 am Sample Type: S

| Department / Test / Parameter | Result | Units | Method | R.L. | DF | Prep Date | By | Analysis Date | By |
|-------------------------------|--------|-------|--------|------|----|-----------|----|---------------|----|
|-------------------------------|--------|-------|--------|------|----|-----------|----|---------------|----|

Metals

Lead 41.1 µg/L EPA 200.8 1.00 1 11/09/16 RPV 11/14/16 14:15 RPV

Sample Number: 6112158-11 Site: OTW-WC-1FL-HALLB-1 Sample ID: Waretown Elementary School
 Collector: DT Collect Date: 11/08/2016 12:07 am Sample Type: S

| Department / Test / Parameter | Result | Units | Method | R.L. | DF | Prep Date | By | Analysis Date | By |
|-------------------------------|--------|-------|--------|------|----|-----------|----|---------------|----|
|-------------------------------|--------|-------|--------|------|----|-----------|----|---------------|----|

Metals

Lead < 1.00 µg/L EPA 200.8 1.00 1 11/09/16 RPV 11/14/16 14:20 RPV

Sample Number: 6112158-12 Site: OTW-WC-1FL-HALLB-2 Sample ID: Waretown Elementary School
 Collector: DT Collect Date: 11/08/2016 12:08 am Sample Type: S

| Department / Test / Parameter | Result | Units | Method | R.L. | DF | Prep Date | By | Analysis Date | By |
|-------------------------------|--------|-------|--------|------|----|-----------|----|---------------|----|
|-------------------------------|--------|-------|--------|------|----|-----------|----|---------------|----|

Metals

Lead < 1.00 µg/L EPA 200.8 1.00 1 11/09/16 RPV 11/14/16 14:22 RPV

Report Generated On: 11/15/2016 5:00 pm 6112158
 STL_Results Revision #1.6 Effective: 07/09/2014





Sample Number: 6112158-13 Site: OTW-DW-1FL-HALLA Sample ID: Waretown Elementary School
Collector: DT Collect Date: 11/08/2016 12:11 am Sample Type: S

| Department / Test / Parameter | Result | Units | Method | R.L. | DF | Prep Date | By | Analysis Date | By |
|-------------------------------|--------|-------|--------|------|----|-----------|----|---------------|----|
|-------------------------------|--------|-------|--------|------|----|-----------|----|---------------|----|

Metals

Lead 1.13 µg/L EPA 200.8 1.00 1 11/09/16 RPV 11/14/16 14:24 RPV

Sample Number: 6112158-14 Site: OTW-CS-1FL-ROOM39 Sample ID: Waretown Elementary School
Collector: DT Collect Date: 11/08/2016 12:15 am Sample Type: S

| Department / Test / Parameter | Result | Units | Method | R.L. | DF | Prep Date | By | Analysis Date | By |
|-------------------------------|--------|-------|--------|------|----|-----------|----|---------------|----|
|-------------------------------|--------|-------|--------|------|----|-----------|----|---------------|----|

Metals

Lead 4.44 µg/L EPA 200.8 1.00 1 11/09/16 RPV 11/14/16 14:26 RPV

Sample Number: 6112158-15 Site: OTW-DW-1FL-ROOM39 Sample ID: Waretown Elementary School
Collector: DT Collect Date: 11/08/2016 12:16 am Sample Type: S

| Department / Test / Parameter | Result | Units | Method | R.L. | DF | Prep Date | By | Analysis Date | By |
|-------------------------------|--------|-------|--------|------|----|-----------|----|---------------|----|
|-------------------------------|--------|-------|--------|------|----|-----------|----|---------------|----|

Metals

Lead 4.97 µg/L EPA 200.8 1.00 1 11/09/16 RPV 11/14/16 14:28 RPV

Sample Number: 6112158-16 Site: OTW-CS-1FL-ROOM42 Sample ID: Waretown Elementary School
Collector: DT Collect Date: 11/08/2016 12:22 am Sample Type: S

| Department / Test / Parameter | Result | Units | Method | R.L. | DF | Prep Date | By | Analysis Date | By |
|-------------------------------|--------|-------|--------|------|----|-----------|----|---------------|----|
|-------------------------------|--------|-------|--------|------|----|-----------|----|---------------|----|

Metals

Lead 8.45 µg/L EPA 200.8 1.00 1 11/09/16 RPV 11/14/16 14:34 RPV

Sample Number: 6112158-17 Site: OTW-DW-1FL-ROOM42 Sample ID: Waretown Elementary School
Collector: DT Collect Date: 11/08/2016 12:23 am Sample Type: S

| Department / Test / Parameter | Result | Units | Method | R.L. | DF | Prep Date | By | Analysis Date | By |
|-------------------------------|--------|-------|--------|------|----|-----------|----|---------------|----|
|-------------------------------|--------|-------|--------|------|----|-----------|----|---------------|----|

Metals

Lead 12.2 µg/L EPA 200.8 1.00 1 11/09/16 RPV 11/14/16 14:43 RPV

Sample Number: 6112158-18 Site: OTW-CS-1FL-ROOM41 Sample ID: Waretown Elementary School
Collector: DT Collect Date: 11/08/2016 12:26 am Sample Type: S

| Department / Test / Parameter | Result | Units | Method | R.L. | DF | Prep Date | By | Analysis Date | By |
|-------------------------------|--------|-------|--------|------|----|-----------|----|---------------|----|
|-------------------------------|--------|-------|--------|------|----|-----------|----|---------------|----|

Metals

Lead 14.7 µg/L EPA 200.8 1.00 1 11/09/16 RPV 11/14/16 14:45 RPV

Report Generated On: 11/15/2016 5:00 pm 6112158
STL_Results Revision #1.6 Effective: 07/09/2014





SUBURBAN TESTING LABS

Sample Number: 6112158-19 Site: OTW-DW-1FL-ROOM41 Sample ID: Waretown Elementary School
 Collector: DT Collect Date: 11/08/2016 12:27 am Sample Type: S

| Department / Test / Parameter | Result | Units | Method | R.L. | DF | Prep Date | By | Analysis Date | By |
|-------------------------------|--------|-------|--------|------|----|-----------|----|---------------|----|
|-------------------------------|--------|-------|--------|------|----|-----------|----|---------------|----|

Metals

Lead 3.63 µg/L EPA 200.8 1.00 1 11/09/16 RPV 11/14/16 14:47 RPV

Sample Number: 6112158-20 Site: OTW-CS-1FL-ROOM40 Sample ID: Waretown Elementary School
 Collector: DT Collect Date: 11/08/2016 12:30 am Sample Type: S

| Department / Test / Parameter | Result | Units | Method | R.L. | DF | Prep Date | By | Analysis Date | By |
|-------------------------------|--------|-------|--------|------|----|-----------|----|---------------|----|
|-------------------------------|--------|-------|--------|------|----|-----------|----|---------------|----|

Metals

Lead 1.72 µg/L EPA 200.8 1.00 1 11/09/16 RPV 11/14/16 14:49 RPV

Sample Number: 6112158-21 Site: OTW-DW-1FL-ROOM40 Sample ID: Waretown Elementary School
 Collector: DT Collect Date: 11/08/2016 12:31 am Sample Type: S

| Department / Test / Parameter | Result | Units | Method | R.L. | DF | Prep Date | By | Analysis Date | By |
|-------------------------------|--------|-------|--------|------|----|-----------|----|---------------|----|
|-------------------------------|--------|-------|--------|------|----|-----------|----|---------------|----|

Metals

Lead 2.26 µg/L EPA 200.8 1.00 1 11/09/16 RPV 11/14/16 14:51 RPV

Sample Number: 6112158-22 Site: OTW-CS-1FL-ROOM33 Sample ID: Waretown Elementary School
 Collector: DT Collect Date: 11/08/2016 12:35 am Sample Type: S

| Department / Test / Parameter | Result | Units | Method | R.L. | DF | Prep Date | By | Analysis Date | By |
|-------------------------------|--------|-------|--------|------|----|-----------|----|---------------|----|
|-------------------------------|--------|-------|--------|------|----|-----------|----|---------------|----|

Metals

Lead 1.98 µg/L EPA 200.8 1.00 1 11/09/16 RPV 11/14/16 14:53 RPV

Sample Number: 6112158-23 Site: OTW-DW-1FL-ROOM33 Sample ID: Waretown Elementary School
 Collector: DT Collect Date: 11/08/2016 12:36 am Sample Type: S

| Department / Test / Parameter | Result | Units | Method | R.L. | DF | Prep Date | By | Analysis Date | By |
|-------------------------------|--------|-------|--------|------|----|-----------|----|---------------|----|
|-------------------------------|--------|-------|--------|------|----|-----------|----|---------------|----|

Metals

Lead 1.62 µg/L EPA 200.8 1.00 1 11/09/16 RPV 11/14/16 14:55 RPV

Sample Number: 6112158-24 Site: OTW-DW-1FL-ROOM33.5 Sample ID: Waretown Elementary School
 Collector: DT Collect Date: 11/08/2016 12:43 am Sample Type: S

| Department / Test / Parameter | Result | Units | Method | R.L. | DF | Prep Date | By | Analysis Date | By |
|-------------------------------|--------|-------|--------|------|----|-----------|----|---------------|----|
|-------------------------------|--------|-------|--------|------|----|-----------|----|---------------|----|

Metals

Lead 3.22 µg/L EPA 200.8 1.00 1 11/09/16 RPV 11/14/16 14:57 RPV

Report Generated On: 11/15/2016 5:00 pm 6112158
 STL_Results Revision #1.6 Effective: 07/09/2014





SUBURBAN TESTING LABS

Sample Number: 6112158-25 Site: OTW-CS-1FL-ROOM32 Sample ID: Waretown Elementary School
 Collector: DT Collect Date: 11/08/2016 12:46 am Sample Type: S

| Department / Test / Parameter | Result | Units | Method | R.L. | DF | Prep Date | By | Analysis Date | By |
|-------------------------------|--------|-------|--------|------|----|-----------|----|---------------|----|
|-------------------------------|--------|-------|--------|------|----|-----------|----|---------------|----|

Metals

Lead 1.45 µg/L EPA 200.8 1.00 1 11/09/16 RPV 11/14/16 14:59 RPV

Sample Number: 6112158-26 Site: OTW-CS-1FL-ROOM31 Sample ID: Waretown Elementary School
 Collector: DT Collect Date: 11/08/2016 12:48 am Sample Type: S

| Department / Test / Parameter | Result | Units | Method | R.L. | DF | Prep Date | By | Analysis Date | By |
|-------------------------------|--------|-------|--------|------|----|-----------|----|---------------|----|
|-------------------------------|--------|-------|--------|------|----|-----------|----|---------------|----|

Metals

Lead 1.10 µg/L EPA 200.8 1.00 1 11/09/16 RPV 11/14/16 15:08 RPV

Sample Number: 6112158-27 Site: OTW-CS-1FL-ROOM49 Sample ID: Waretown Elementary School
 Collector: DT Collect Date: 11/08/2016 12:51 am Sample Type: S

| Department / Test / Parameter | Result | Units | Method | R.L. | DF | Prep Date | By | Analysis Date | By |
|-------------------------------|--------|-------|--------|------|----|-----------|----|---------------|----|
|-------------------------------|--------|-------|--------|------|----|-----------|----|---------------|----|

Metals

Lead < 1.00 µg/L EPA 200.8 1.00 1 11/09/16 RPV 11/14/16 15:01 RPV

Sample Number: 6112158-28 Site: OTW-CS-1FL-ROOM30 Sample ID: Waretown Elementary School
 Collector: DT Collect Date: 11/08/2016 12:54 am Sample Type: S

| Department / Test / Parameter | Result | Units | Method | R.L. | DF | Prep Date | By | Analysis Date | By |
|-------------------------------|--------|-------|--------|------|----|-----------|----|---------------|----|
|-------------------------------|--------|-------|--------|------|----|-----------|----|---------------|----|

Metals

Lead < 1.00 µg/L EPA 200.8 1.00 1 11/09/16 RPV 11/14/16 15:07 RPV

Sample Number: 6112158-29 Site: OTW-NS-1FL-NURSEBATH Sample ID: Waretown Elementary School
 Collector: DT Collect Date: 11/08/2016 12:58 am Sample Type: S

| Department / Test / Parameter | Result | Units | Method | R.L. | DF | Prep Date | By | Analysis Date | By |
|-------------------------------|--------|-------|--------|------|----|-----------|----|---------------|----|
|-------------------------------|--------|-------|--------|------|----|-----------|----|---------------|----|

Metals

Lead < 1.00 µg/L EPA 200.8 1.00 1 11/09/16 RPV 11/14/16 15:12 RPV

Sample Number: 6112158-30 Site: OTW-NS-1FL-NURSERESOURCE Sample ID: Waretown Elementary School
 Collector: DT Collect Date: 11/08/2016 12:59 am Sample Type: S

| Department / Test / Parameter | Result | Units | Method | R.L. | DF | Prep Date | By | Analysis Date | By |
|-------------------------------|--------|-------|--------|------|----|-----------|----|---------------|----|
|-------------------------------|--------|-------|--------|------|----|-----------|----|---------------|----|

Metals

Lead 6.81 µg/L EPA 200.8 1.00 1 11/09/16 RPV 11/14/16 15:14 RPV

Report Generated On: 11/15/2016 5:00 pm 6112158
 STL_Results Revision #1.6 Effective: 07/09/2014





SUBURBAN TESTING LABS

Sample Number: 6112158-31 Site: OTW-WC-1FL-HALLC-1 Sample ID: Waretown Elementary School
 Collector: DT Collect Date: 11/08/2016 1:04 am Sample Type: S

| Department / Test / Parameter | Result | Units | Method | R.L. | DF | Prep Date | By | Analysis Date | By |
|-------------------------------|--------|-------|--------|------|----|-----------|----|---------------|----|
|-------------------------------|--------|-------|--------|------|----|-----------|----|---------------|----|

Metals

Lead < 1.00 µg/L EPA 200.8 1.00 1 11/09/16 RPV 11/14/16 15:16 RPV

Sample Number: 6112158-32 Site: OTW-WC-1FL-HALLC-2 Sample ID: Waretown Elementary School
 Collector: DT Collect Date: 11/08/2016 1:04 am Sample Type: S

| Department / Test / Parameter | Result | Units | Method | R.L. | DF | Prep Date | By | Analysis Date | By |
|-------------------------------|--------|-------|--------|------|----|-----------|----|---------------|----|
|-------------------------------|--------|-------|--------|------|----|-----------|----|---------------|----|

Metals

Lead < 1.00 µg/L EPA 200.8 1.00 1 11/09/16 RPV 11/14/16 15:18 RPV

Sample Number: 6112158-33 Site: OTW-TL-1FL-FACULTY Sample ID: Waretown Elementary School
 Collector: DT Collect Date: 11/08/2016 1:11 am Sample Type: S

| Department / Test / Parameter | Result | Units | Method | R.L. | DF | Prep Date | By | Analysis Date | By |
|-------------------------------|--------|-------|--------|------|----|-----------|----|---------------|----|
|-------------------------------|--------|-------|--------|------|----|-----------|----|---------------|----|

Metals

Lead < 1.00 µg/L EPA 200.8 1.00 1 11/09/16 RPV 11/14/16 15:20 RPV

Sample Number: 6112158-34 Site: OTW-CS-1FL-ROOM22 Sample ID: Waretown Elementary School
 Collector: DT Collect Date: 11/08/2016 1:20 am Sample Type: S

| Department / Test / Parameter | Result | Units | Method | R.L. | DF | Prep Date | By | Analysis Date | By |
|-------------------------------|--------|-------|--------|------|----|-----------|----|---------------|----|
|-------------------------------|--------|-------|--------|------|----|-----------|----|---------------|----|

Metals

Lead 1.17 µg/L EPA 200.8 1.00 1 11/09/16 RPV 11/14/16 15:22 RPV

Sample Number: 6112158-35 Site: OTW-DW-1FL-ROOM22 Sample ID: Waretown Elementary School
 Collector: DT Collect Date: 11/08/2016 1:21 am Sample Type: S

| Department / Test / Parameter | Result | Units | Method | R.L. | DF | Prep Date | By | Analysis Date | By |
|-------------------------------|--------|-------|--------|------|----|-----------|----|---------------|----|
|-------------------------------|--------|-------|--------|------|----|-----------|----|---------------|----|

Metals

Lead < 1.00 µg/L EPA 200.8 1.00 1 11/09/16 RPV 11/14/16 15:24 RPV

Sample Number: 6112158-36 Site: OTW-CS-1FL-ROOM27 Sample ID: Waretown Elementary School
 Collector: DT Collect Date: 11/08/2016 1:24 am Sample Type: S

| Department / Test / Parameter | Result | Units | Method | R.L. | DF | Prep Date | By | Analysis Date | By |
|-------------------------------|--------|-------|--------|------|----|-----------|----|---------------|----|
|-------------------------------|--------|-------|--------|------|----|-----------|----|---------------|----|

Metals

Lead 2.81 µg/L EPA 200.8 1.00 1 11/09/16 RPV 11/14/16 15:34 RPV

Report Generated On: 11/15/2016 5:00 pm 6112158
 STL_Results Revision #1.6 Effective: 07/09/2014





SUBURBAN TESTING LABS

Sample Number: 6112158-37 Site: OTW-DW-1FL-ROOM27 Sample ID: Waretown Elementary School
 Collector: DT Collect Date: 11/08/2016 1:25 am Sample Type: S

| Department / Test / Parameter | Result | Units | Method | R.L. | DF | Prep Date | By | Analysis Date | By |
|-------------------------------|--------|-------|--------|------|----|-----------|----|---------------|----|
|-------------------------------|--------|-------|--------|------|----|-----------|----|---------------|----|

Metals

Lead 1.93 µg/L EPA 200.8 1.00 1 11/09/16 RPV 11/14/16 15:39 RPV

Sample Number: 6112158-38 Site: OTW-CS-1FL-ROOM26 Sample ID: Waretown Elementary School
 Collector: DT Collect Date: 11/08/2016 1:29 am Sample Type: S

| Department / Test / Parameter | Result | Units | Method | R.L. | DF | Prep Date | By | Analysis Date | By |
|-------------------------------|--------|-------|--------|------|----|-----------|----|---------------|----|
|-------------------------------|--------|-------|--------|------|----|-----------|----|---------------|----|

Metals

Lead 1.40 µg/L EPA 200.8 1.00 1 11/09/16 RPV 11/14/16 15:41 RPV

Sample Number: 6112158-39 Site: OTW-DW-1FL-ROOM26 Sample ID: Waretown Elementary School
 Collector: DT Collect Date: 11/08/2016 1:30 am Sample Type: S

| Department / Test / Parameter | Result | Units | Method | R.L. | DF | Prep Date | By | Analysis Date | By |
|-------------------------------|--------|-------|--------|------|----|-----------|----|---------------|----|
|-------------------------------|--------|-------|--------|------|----|-----------|----|---------------|----|

Metals

Lead < 1.00 µg/L EPA 200.8 1.00 1 11/09/16 RPV 11/14/16 15:43 RPV

Sample Number: 6112158-40 Site: OTW-CS-1FL-ROOM25-1 Sample ID: Waretown Elementary School
 Collector: DT Collect Date: 11/08/2016 1:33 am Sample Type: S

| Department / Test / Parameter | Result | Units | Method | R.L. | DF | Prep Date | By | Analysis Date | By |
|-------------------------------|--------|-------|--------|------|----|-----------|----|---------------|----|
|-------------------------------|--------|-------|--------|------|----|-----------|----|---------------|----|

Metals

Lead 1.44 µg/L EPA 200.8 1.00 1 11/09/16 RPV 11/14/16 15:45 RPV

Sample Number: 6112158-41 Site: OTW-CS-1FL-ROOM25-2 Sample ID: Waretown Elementary School
 Collector: DT Collect Date: 11/08/2016 1:33 am Sample Type: S

| Department / Test / Parameter | Result | Units | Method | R.L. | DF | Prep Date | By | Analysis Date | By |
|-------------------------------|--------|-------|--------|------|----|-----------|----|---------------|----|
|-------------------------------|--------|-------|--------|------|----|-----------|----|---------------|----|

Metals

Lead 5.84 µg/L EPA 200.8 1.00 1 11/09/16 RPV 11/14/16 15:47 RPV

Sample Number: 6112158-42 Site: OTW-CS-1FL-ROOM23 Sample ID: Waretown Elementary School
 Collector: DT Collect Date: 11/08/2016 1:39 am Sample Type: S

| Department / Test / Parameter | Result | Units | Method | R.L. | DF | Prep Date | By | Analysis Date | By |
|-------------------------------|--------|-------|--------|------|----|-----------|----|---------------|----|
|-------------------------------|--------|-------|--------|------|----|-----------|----|---------------|----|

Metals

Lead 2.09 µg/L EPA 200.8 1.00 1 11/09/16 RPV 11/14/16 15:53 RPV

Report Generated On: 11/15/2016 5:00 pm 6112158
 STL_Results Revision #1.6 Effective: 07/09/2014





Sample Number: 6112158-43 Site: OTW-DW-1FL-ROOM23 Sample ID: Waretown Elementary School
Collector: DT Collect Date: 11/08/2016 1:40 am Sample Type: S

| Department / Test / Parameter | Result | Units | Method | R.L. | DF | Prep Date | By | Analysis Date | By |
|-------------------------------|--------|-------|--------|------|----|-----------|----|---------------|----|
|-------------------------------|--------|-------|--------|------|----|-----------|----|---------------|----|

Metals

Lead 2.92 µg/L EPA 200.8 1.00 1 11/09/16 RPV 11/14/16 15:55 RPV

Sample Number: 6112158-44 Site: OTW-KC-1FL-ROOM1 Sample ID: Waretown Elementary School
Collector: DT Collect Date: 11/08/2016 1:15 am Sample Type: S

| Department / Test / Parameter | Result | Units | Method | R.L. | DF | Prep Date | By | Analysis Date | By |
|-------------------------------|--------|-------|--------|------|----|-----------|----|---------------|----|
|-------------------------------|--------|-------|--------|------|----|-----------|----|---------------|----|

Metals

Lead < 1.00 µg/L EPA 200.8 1.00 1 11/09/16 RPV 11/14/16 15:57 RPV

Sample Number: 6112158-45 Site: OTW-CS-1FL-ROOM10 Sample ID: Waretown Elementary School
Collector: DT Collect Date: 11/08/2016 1:45 am Sample Type: S

| Department / Test / Parameter | Result | Units | Method | R.L. | DF | Prep Date | By | Analysis Date | By |
|-------------------------------|--------|-------|--------|------|----|-----------|----|---------------|----|
|-------------------------------|--------|-------|--------|------|----|-----------|----|---------------|----|

Metals

Lead 4.35 µg/L EPA 200.8 1.00 1 11/09/16 RPV 11/14/16 15:59 RPV

Sample Number: 6112158-46 Site: OTW-DW-1FL-ROOM10 Sample ID: Waretown Elementary School
Collector: DT Collect Date: 11/08/2016 1:46 am Sample Type: S

| Department / Test / Parameter | Result | Units | Method | R.L. | DF | Prep Date | By | Analysis Date | By |
|-------------------------------|--------|-------|--------|------|----|-----------|----|---------------|----|
|-------------------------------|--------|-------|--------|------|----|-----------|----|---------------|----|

Metals

Lead < 1.00 µg/L EPA 200.8 1.00 1 11/09/16 RPV 11/14/16 16:01 RPV

Sample Number: 6112158-47 Site: OTW-CS-1FL-ROOM17 Sample ID: Waretown Elementary School
Collector: DT Collect Date: 11/08/2016 1:50 am Sample Type: S

| Department / Test / Parameter | Result | Units | Method | R.L. | DF | Prep Date | By | Analysis Date | By |
|-------------------------------|--------|-------|--------|------|----|-----------|----|---------------|----|
|-------------------------------|--------|-------|--------|------|----|-----------|----|---------------|----|

Metals

Lead < 1.00 µg/L EPA 200.8 1.00 1 11/09/16 RPV 11/14/16 16:05 RPV

Sample Number: 6112158-48 Site: OTW-DW-1FL-ROOM17 Sample ID: Waretown Elementary School
Collector: DT Collect Date: 11/08/2016 1:51 am Sample Type: S

| Department / Test / Parameter | Result | Units | Method | R.L. | DF | Prep Date | By | Analysis Date | By |
|-------------------------------|--------|-------|--------|------|----|-----------|----|---------------|----|
|-------------------------------|--------|-------|--------|------|----|-----------|----|---------------|----|

Metals

Lead < 1.00 µg/L EPA 200.8 1.00 1 11/09/16 RPV 11/14/16 16:07 RPV

Report Generated On: 11/15/2016 5:00 pm 6112158
STL_Results Revision #1.6 Effective: 07/09/2014





Sample Number: 6112158-49 Site: OTW-CS-1FL-ROOM12 Sample ID: Waretown Elementary School
Collector: DT Collect Date: 11/08/2016 1:53 am Sample Type: S

| Department / Test / Parameter | Result | Units | Method | R.L. | DF | Prep Date | By | Analysis Date | By |
|-------------------------------|--------|-------|--------|------|----|-----------|----|---------------|----|
|-------------------------------|--------|-------|--------|------|----|-----------|----|---------------|----|

Metals

Lead < 1.00 µg/L EPA 200.8 1.00 1 11/09/16 RPV 11/14/16 16:09 RPV

Sample Number: 6112158-50 Site: OTW-DW-1FL-ROOM12 Sample ID: Waretown Elementary School
Collector: DT Collect Date: 11/08/2016 1:54 am Sample Type: S

| Department / Test / Parameter | Result | Units | Method | R.L. | DF | Prep Date | By | Analysis Date | By |
|-------------------------------|--------|-------|--------|------|----|-----------|----|---------------|----|
|-------------------------------|--------|-------|--------|------|----|-----------|----|---------------|----|

Metals

Lead < 1.00 µg/L EPA 200.8 1.00 1 11/09/16 RPV 11/14/16 16:13 RPV

Sample Number: 6112158-51 Site: OTW-CS-1FL-ROOM16 Sample ID: Waretown Elementary School
Collector: DT Collect Date: 11/08/2016 1:58 am Sample Type: S

| Department / Test / Parameter | Result | Units | Method | R.L. | DF | Prep Date | By | Analysis Date | By |
|-------------------------------|--------|-------|--------|------|----|-----------|----|---------------|----|
|-------------------------------|--------|-------|--------|------|----|-----------|----|---------------|----|

Metals

Lead < 1.00 µg/L EPA 200.8 1.00 1 11/09/16 RPV 11/14/16 16:23 RPV

Sample Number: 6112158-52 Site: OTW-DW-1FL-ROOM16 Sample ID: Waretown Elementary School
Collector: DT Collect Date: 11/08/2016 1:59 am Sample Type: S

| Department / Test / Parameter | Result | Units | Method | R.L. | DF | Prep Date | By | Analysis Date | By |
|-------------------------------|--------|-------|--------|------|----|-----------|----|---------------|----|
|-------------------------------|--------|-------|--------|------|----|-----------|----|---------------|----|

Metals

Lead < 1.00 µg/L EPA 200.8 1.00 1 11/09/16 RPV 11/14/16 16:25 RPV

Sample Number: 6112158-53 Site: OTW-CS-1FL-ROOM13 Sample ID: Waretown Elementary School
Collector: DT Collect Date: 11/08/2016 2:02 am Sample Type: S

| Department / Test / Parameter | Result | Units | Method | R.L. | DF | Prep Date | By | Analysis Date | By |
|-------------------------------|--------|-------|--------|------|----|-----------|----|---------------|----|
|-------------------------------|--------|-------|--------|------|----|-----------|----|---------------|----|

Metals

Lead < 1.00 µg/L EPA 200.8 1.00 1 11/09/16 RPV 11/14/16 16:27 RPV

Sample Number: 6112158-54 Site: OTW-DW-1FL-ROOM13 Sample ID: Waretown Elementary School
Collector: DT Collect Date: 11/08/2016 2:03 am Sample Type: S

| Department / Test / Parameter | Result | Units | Method | R.L. | DF | Prep Date | By | Analysis Date | By |
|-------------------------------|--------|-------|--------|------|----|-----------|----|---------------|----|
|-------------------------------|--------|-------|--------|------|----|-----------|----|---------------|----|

Metals

Lead < 1.00 µg/L EPA 200.8 1.00 1 11/09/16 RPV 11/14/16 16:29 RPV

Report Generated On: 11/15/2016 5:00 pm 6112158
STL_Results Revision #1.6 Effective: 07/09/2014





SUBURBAN TESTING LABS

Sample Number: 6112158-55 Site: OTW-CS-1FL-ROOM14 Sample ID: Waretown Elementary School
 Collector: DT Collect Date: 11/08/2016 2:06 am Sample Type: S

| Department / Test / Parameter | Result | Units | Method | R.L. | DF | Prep Date | By | Analysis Date | By |
|-------------------------------|--------|-------|--------|------|----|-----------|----|---------------|----|
|-------------------------------|--------|-------|--------|------|----|-----------|----|---------------|----|

Metals

Lead < 1.00 µg/L EPA 200.8 1.00 1 11/09/16 RPV 11/14/16 16:31 RPV

Sample Number: 6112158-56 Site: OTW-DW-1FL-ROOM14 Sample ID: Waretown Elementary School
 Collector: DT Collect Date: 11/08/2016 2:07 am Sample Type: S

| Department / Test / Parameter | Result | Units | Method | R.L. | DF | Prep Date | By | Analysis Date | By |
|-------------------------------|--------|-------|--------|------|----|-----------|----|---------------|----|
|-------------------------------|--------|-------|--------|------|----|-----------|----|---------------|----|

Metals

Lead < 1.00 µg/L EPA 200.8 1.00 1 11/09/16 RPV 11/14/16 16:36 RPV

Sample Number: 6112158-57 Site: OTW-CS-1FL-ROOM15 Sample ID: Waretown Elementary School
 Collector: DT Collect Date: 11/08/2016 2:10 am Sample Type: S

| Department / Test / Parameter | Result | Units | Method | R.L. | DF | Prep Date | By | Analysis Date | By |
|-------------------------------|--------|-------|--------|------|----|-----------|----|---------------|----|
|-------------------------------|--------|-------|--------|------|----|-----------|----|---------------|----|

Metals

Lead 1.35 µg/L EPA 200.8 1.00 1 11/09/16 RPV 11/14/16 16:46 RPV

Sample Number: 6112158-58 Site: OTW-DW-1FL-ROOM15 Sample ID: Waretown Elementary School
 Collector: DT Collect Date: 11/08/2016 2:11 am Sample Type: S

| Department / Test / Parameter | Result | Units | Method | R.L. | DF | Prep Date | By | Analysis Date | By |
|-------------------------------|--------|-------|--------|------|----|-----------|----|---------------|----|
|-------------------------------|--------|-------|--------|------|----|-----------|----|---------------|----|

Metals

Lead < 1.00 µg/L EPA 200.8 1.00 1 11/09/16 RPV 11/14/16 16:48 RPV

Sample Number: 6112158-59 Site: LCS-1 Sample ID: Waretown Elementary School
 Collector: Collect Date: 11/09/2016 12:00 am Sample Type: S

| Department / Test / Parameter | Result | Units | Method | R.L. | DF | Prep Date | By | Analysis Date | By |
|-------------------------------|--------|-------|--------|------|----|-----------|----|---------------|----|
|-------------------------------|--------|-------|--------|------|----|-----------|----|---------------|----|

Metals

Lead 14.8 µg/L EPA 200.8 1.00 1 11/09/16 RPV 11/14/16 16:50 RPV

Sample Number: 6112158-60 Site: LCS-2 Sample ID: Waretown Elementary School
 Collector: Collect Date: 11/09/2016 12:00 am Sample Type: S

| Department / Test / Parameter | Result | Units | Method | R.L. | DF | Prep Date | By | Analysis Date | By |
|-------------------------------|--------|-------|--------|------|----|-----------|----|---------------|----|
|-------------------------------|--------|-------|--------|------|----|-----------|----|---------------|----|

Metals

Lead 14.7 µg/L EPA 200.8 1.00 1 11/09/16 RPV 11/14/16 16:52 RPV

Report Generated On: 11/15/2016 5:00 pm 6112158
 STL_Results Revision #1.6 Effective: 07/09/2014





Sample Number: 6112158-61 Site: LCS-3 Sample ID: Waretown Elementary School
Collector: Collect Date: 11/09/2016 12:00 am Sample Type: S

| Department / Test / Parameter | Result | Units | Method | R.L. | DF | Prep Date | By | Analysis Date | By |
|-------------------------------|--------|-------|--------|------|----|-----------|----|---------------|----|
|-------------------------------|--------|-------|--------|------|----|-----------|----|---------------|----|

Metals

Lead 14.9 µg/L EPA 200.8 1.00 1 11/09/16 RPV 11/14/16 16:54 RPV

Sample Number: 6112158-62 Site: LCS-1-Dup Sample ID: Waretown Elementary School
Collector: Collect Date: 11/09/2016 12:00 am Sample Type: S

| Department / Test / Parameter | Result | Units | Method | R.L. | DF | Prep Date | By | Analysis Date | By |
|-------------------------------|--------|-------|--------|------|----|-----------|----|---------------|----|
|-------------------------------|--------|-------|--------|------|----|-----------|----|---------------|----|

Metals

Lead 14.7 µg/L EPA 200.8 1.00 1 11/09/16 RPV 11/14/16 16:56 RPV

Sample Number: 6112158-63 Site: LCS-2-Dup Sample ID: Waretown Elementary School
Collector: Collect Date: 11/09/2016 12:00 am Sample Type: S

| Department / Test / Parameter | Result | Units | Method | R.L. | DF | Prep Date | By | Analysis Date | By |
|-------------------------------|--------|-------|--------|------|----|-----------|----|---------------|----|
|-------------------------------|--------|-------|--------|------|----|-----------|----|---------------|----|

Metals

Lead 14.6 µg/L EPA 200.8 1.00 1 11/09/16 RPV 11/14/16 16:58 RPV

Sample Number: 6112158-64 Site: LCS-3-Dup Sample ID: Waretown Elementary School
Collector: Collect Date: 11/09/2016 12:00 am Sample Type: S

| Department / Test / Parameter | Result | Units | Method | R.L. | DF | Prep Date | By | Analysis Date | By |
|-------------------------------|--------|-------|--------|------|----|-----------|----|---------------|----|
|-------------------------------|--------|-------|--------|------|----|-----------|----|---------------|----|

Metals

Lead 14.5 µg/L EPA 200.8 1.00 1 11/09/16 RPV 11/14/16 17:00 RPV

Data Qualifiers:

Sample Receipt Conditions:
All samples met the sample receipt requirements for the relevant analyses.

** This report has been Amended (Rev1) and replaces all previous reports for this order ID **

All results meet the requirements of STL's TNI (NELAC) Accredited Quality System unless otherwise noted. If your results contain any data qualifiers or comments, you should evaluate useability relative to your needs.

If collectors initials include "STL", samples have been collected in accordance with STL SOP SL0015.

All results reported on an As Received (Wet Weight) basis unless otherwise noted.

This laboratory report may not be reproduced, except in full, without the written approval of STL.

Results are considered Preliminary unless report is signed by authorized representative of STL.

Report Generated On: 11/15/2016 5:00 pm 6112158
STL_Results Revision #1.6 Effective: 07/09/2014





SUBURBAN
TESTING LABS

Reviewed and Released By:

William Smith
Technical Director

Report Generated On: 11/15/2016 5:00 pm 6112158
STL_Results Revision #1.6 Effective: 07/09/2014

