

November 28, 2016

Ocean Township School District
Frederic A. Priff Elementary School
139 Wells Mills Road
Waretown, NJ 08758

Dear Frederic A. Priff Elementary School Community,

Our school system is committed to protecting student, teacher, and staff health. To protect our community and be in compliance with the Department of Education regulations, Ocean Township School District tested our schools' drinking water for lead.

In accordance with the Department of Education regulations, Frederic A. Priff Elementary will implement immediate remedial measures for any drinking water outlet with a result greater than the action level of 15 µg/l (parts per billion [ppb]). This includes turning off the outlet unless it is determined the location must remain on for non-drinking purposes. In these cases, a "DO NOT DRINK – SAFE FOR HANDWASHING ONLY" sign will be posted.

Results of our Testing

Following instructions given in technical guidance developed by the New Jersey Department of Environmental Protection, we completed a plumbing profile for each of the buildings within Ocean Township School District. Through this effort, we identified and tested all drinking water and food preparation outlets. Of the 59 samples taken, all but 4 tested below the lead action level established by the US Environmental Protection Agency for lead in drinking water (15 µg/l [ppb]).

The table below identifies the drinking water outlets that tested above the 15 µg/l for lead, the actual lead level, and what temporary remedial action Ocean Township School District has taken to reduce the levels of lead at these locations.

Location	First Draw Result in µg/l (ppb)	Remedial Action
Boiler Room Service Line Outlet	22.7	Disconnected outlet.
Library Copy Room Sink	44.1	Disconnected outlet.
Room 28	19.9	Disconnected outlet.
Room 27	18.0	Disconnected outlet.

Health Effects of Lead

High levels of lead in drinking water can cause health problems. Lead is most dangerous for pregnant women, infants, and children under 6 years of age. It can cause damage to the brain and kidneys, and can interfere with the production of red blood cells that carry oxygen to all parts of your body. Exposure to high levels of lead during pregnancy contributes to low birth weight and developmental delays in infants. In young children, lead exposure can lower IQ levels, affect hearing, reduce attention span, and hurt school performance. At *very* high levels, lead can even cause brain damage. Adults with kidney problems and high blood pressure can be affected by low levels of lead more than healthy adults.

How Lead Enters our Water

Lead is unusual among drinking water contaminants in that it seldom occurs naturally in water supplies like groundwater, rivers and lakes. Lead enters drinking water primarily as a result of the corrosion, or wearing away, of materials containing lead in the water distribution system and in building plumbing. These materials include lead-based solder used to join copper pipe, brass, and chrome-plated brass faucets. In 1986, Congress banned the use of lead solder containing greater than 0.2% lead, and restricted the lead content of faucets, pipes and other plumbing materials. However, even the lead in plumbing materials meeting these new requirements is subject to corrosion. When water stands in lead pipes or plumbing systems containing lead for several hours or more, the lead may dissolve into the drinking water. This means the first water drawn from the tap in the morning *may* contain fairly high levels of lead.

Lead in Drinking Water

Lead in drinking water, although rarely the sole cause of lead poisoning can significantly increase a person's total lead exposure, particularly the exposure of children under the age of 6. EPA estimates that drinking water can make up 20% or more of a person's total exposure to lead.

For More Information

A copy of the test results is available in our central office for inspection by the public, including students, teachers, other school personnel, and parents, and can be viewed between the hours of 8:30 a.m. and 3:00 p.m. and are also available on our website at www.otsdk6.org. For more information about water quality in our schools, contact Dr. Christopher Lommerin at the Superintendent Office, 609-693-3131 x130.

For more information on reducing lead exposure around your home and the health effects of lead, visit EPA's Web site at www.epa.gov/lead, call the National Lead Information Center at 800-424-LEAD, or contact your health care provider.

If you are concerned about lead exposure at this facility or in your home, you may want to ask your health care providers about testing children to determine levels of lead in their blood.

Sincerely,

Christopher Lommerin
Superintendent of Schools



Results Report

Order ID: 6112160

Karl Environmental Group
20 Lauck Road
Mohnton, PA 19540

Project: PA/NJ Lead & Copper 2016

Attn: Kelly Mays

Regulatory ID:

Sample Number: 6112160-01	Site: OTF-BLANK	Sample ID: Frederic A. Priff Elementary School
Collector: AS	Collect Date: 11/07/2016 11:32 pm	Sample Type: S

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	< 1.00	µg/L	EPA 200.8	1.00	1	11/09/16	RPV	11/14/16 17:02	RPV
------	--------	------	-----------	------	---	----------	-----	----------------	-----

Sample Number: 6112160-02	Site: OTF-SL-1FL-BOILER	Sample ID: Frederic A. Priff Elementary School
Collector: AS	Collect Date: 11/07/2016 11:35 pm	Sample Type: S

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	22.7	µg/L	EPA 200.8	1.00	1	11/09/16	RPV	11/14/16 17:03	RPV
------	------	------	-----------	------	---	----------	-----	----------------	-----

Sample Number: 6112160-03	Site: OTF-CS-1FL-ROOM1	Sample ID: Frederic A. Priff Elementary School
Collector: AS	Collect Date: 11/07/2016 11:38 pm	Sample Type: S

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	7.92	µg/L	EPA 200.8	1.00	1	11/09/16	RPV	11/14/16 17:09	RPV
------	------	------	-----------	------	---	----------	-----	----------------	-----

Sample Number: 6112160-04	Site: OTF-CS-1FL-ROOM2-1	Sample ID: Frederic A. Priff Elementary School
Collector: AS	Collect Date: 11/07/2016 11:41 pm	Sample Type: S

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	4.42	µg/L	EPA 200.8	1.00	1	11/09/16	RPV	11/14/16 17:11	RPV
------	------	------	-----------	------	---	----------	-----	----------------	-----

Sample Number: 6112160-05	Site: OTF-CS-1FL-ROOM2-2	Sample ID: Frederic A. Priff Elementary School
Collector: AS	Collect Date: 11/07/2016 11:44 pm	Sample Type: S

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	< 1.00	µg/L	EPA 200.8	1.00	1	11/09/16	RPV	11/14/16 17:13	RPV
------	--------	------	-----------	------	---	----------	-----	----------------	-----

Report Generated On: 11/23/2016 4:34 pm 6112160
 STL_Results Revision #1.6 Effective: 07/09/2014





SUBURBAN TESTING LABS

Sample Number: 6112160-06 Site: OTF-DW-1FL-GYM1 Sample ID: Frederic A. Priff Elementary School
 Collector: AS Collect Date: 11/07/2016 11:48 pm Sample Type: S

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead < 1.00 µg/L EPA 200.8 1.00 1 11/09/16 RPV 11/14/16 17:17 RPV

Sample Number: 6112160-07 Site: OTF-DW-1FL-GYM2 Sample ID: Frederic A. Priff Elementary School
 Collector: AS Collect Date: 11/07/2016 11:50 pm Sample Type: S

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead < 1.00 µg/L EPA 200.8 1.00 1 11/09/16 RPV 11/14/16 17:19 RPV

Sample Number: 6112160-08 Site: OTF-KC-1FL-KITCHEN-1 Sample ID: Frederic A. Priff Elementary School
 Collector: AS Collect Date: 11/07/2016 11:53 pm Sample Type: S

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead 1.62 µg/L EPA 200.8 1.00 1 11/09/16 RPV 11/14/16 17:21 RPV

Sample Number: 6112160-09 Site: OTF-KC-1FL-KITCHEN-2 Sample ID: Frederic A. Priff Elementary School
 Collector: AS Collect Date: 11/07/2016 11:55 pm Sample Type: S

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead 3.22 µg/L EPA 200.8 1.00 1 11/09/16 RPV 11/14/16 17:23 RPV

Sample Number: 6112160-10 Site: OTF-KC-1FL-KITCHEN-3 Sample ID: Frederic A. Priff Elementary School
 Collector: AS Collect Date: 11/07/2016 11:57 pm Sample Type: S

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead 5.31 µg/L EPA 200.8 1.00 1 11/09/16 RPV 11/14/16 17:25 RPV

Sample Number: 6112160-11 Site: OTF-CV-1FL-KITCHEN-2 Sample ID: Frederic A. Priff Elementary School
 Collector: AS Collect Date: 11/08/2016 12:04 am Sample Type: S

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead 6.16 µg/L EPA 200.8 1.00 1 11/09/16 RPV 11/14/16 17:27 RPV

Report Generated On: 11/23/2016 4:34 pm 6112160
 STL_Results Revision #1.6 Effective: 07/09/2014





SUBURBAN TESTING LABS

Sample Number: 6112160-12 Site: OTF-CS-1FL-ROOM3 Sample ID: Frederic A. Priff Elementary School
 Collector: AS Collect Date: 11/08/2016 12:10 am Sample Type: S

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead 6.71 µg/L EPA 200.8 1.00 1 11/09/16 RPV 11/14/16 17:32 RPV

Sample Number: 6112160-13 Site: OTF-DW-1FL-ROOM3 Sample ID: Frederic A. Priff Elementary School
 Collector: AS Collect Date: 11/08/2016 12:12 am Sample Type: S

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead 1.30 µg/L EPA 200.8 1.00 1 11/09/16 RPV 11/14/16 17:34 RPV

Sample Number: 6112160-14 Site: OTF-CS-1FL-ROOM4 Sample ID: Frederic A. Priff Elementary School
 Collector: AS Collect Date: 11/08/2016 12:20 am Sample Type: S

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead 7.90 µg/L EPA 200.8 1.00 1 11/09/16 RPV 11/14/16 17:36 RPV

Sample Number: 6112160-15 Site: OTF-DW-1FL-ROOM4 Sample ID: Frederic A. Priff Elementary School
 Collector: AS Collect Date: 11/08/2016 12:22 am Sample Type: S

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead 8.71 µg/L EPA 200.8 1.00 1 11/09/16 RPV 11/14/16 18:20 RPV

Sample Number: 6112160-16 Site: OTF-NS-1FL-NURSE Sample ID: Frederic A. Priff Elementary School
 Collector: AS Collect Date: 11/08/2016 12:26 am Sample Type: S

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead 5.68 µg/L EPA 200.8 1.00 1 11/09/16 RPV 11/14/16 18:26 RPV

Sample Number: 6112160-17 Site: OTF-TL-1FL-FACULTY Sample ID: Frederic A. Priff Elementary School
 Collector: AS Collect Date: 11/08/2016 12:28 am Sample Type: S

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead < 1.00 µg/L EPA 200.8 1.00 1 11/09/16 RPV 11/14/16 18:28 RPV

Report Generated On: 11/23/2016 4:34 pm 6112160
 STL_Results Revision #1.6 Effective: 07/09/2014





SUBURBAN TESTING LABS

Sample Number: 6112160-18 Site: OTF-CS-1FL-ROOM18 Sample ID: Frederic A. Priff Elementary School
 Collector: AS Collect Date: 11/08/2016 12:31 am Sample Type: S

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead 10.1 µg/L EPA 200.8 1.00 1 11/09/16 RPV 11/14/16 18:29 RPV

Sample Number: 6112160-19 Site: OTF-DW-1FL-ROOM18 Sample ID: Frederic A. Priff Elementary School
 Collector: AS Collect Date: 11/08/2016 12:33 am Sample Type: S

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead 1.36 µg/L EPA 200.8 1.00 1 11/09/16 RPV 11/14/16 18:31 RPV

Sample Number: 6112160-20 Site: OTF-CS-1FL-ROOM5 Sample ID: Frederic A. Priff Elementary School
 Collector: AS Collect Date: 11/08/2016 12:38 am Sample Type: S

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead 14.8 µg/L EPA 200.8 1.00 1 11/09/16 RPV 11/14/16 18:33 RPV

Sample Number: 6112160-21 Site: OTF-DW-1FL-ROOM5 Sample ID: Frederic A. Priff Elementary School
 Collector: AS Collect Date: 11/08/2016 12:40 am Sample Type: S

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead 2.05 µg/L EPA 200.8 1.00 1 11/09/16 RPV 11/14/16 18:38 RPV

Sample Number: 6112160-22 Site: OTF-CS-1FL-ROOM19 Sample ID: Frederic A. Priff Elementary School
 Collector: AS Collect Date: 11/08/2016 12:45 am Sample Type: S

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead 4.53 µg/L EPA 200.8 1.00 1 11/09/16 RPV 11/14/16 18:40 RPV

Sample Number: 6112160-23 Site: OTF-DW-1FL-ROOM19 Sample ID: Frederic A. Priff Elementary School
 Collector: AS Collect Date: 11/08/2016 12:47 am Sample Type: S

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead < 1.00 µg/L EPA 200.8 1.00 1 11/09/16 RPV 11/14/16 18:42 RPV

Report Generated On: 11/23/2016 4:34 pm 6112160
 STL_Results Revision #1.6 Effective: 07/09/2014





Sample Number: 6112160-24 Site: OTF-CS-1FL-ROOM6 Sample ID: Frederic A. Priff Elementary School
Collector: AS Collect Date: 11/08/2016 12:50 am Sample Type: S

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead 6.76 µg/L EPA 200.8 1.00 1 11/09/16 RPV 11/14/16 18:44 RPV

Sample Number: 6112160-25 Site: OTF-DW-1FL-ROOM6 Sample ID: Frederic A. Priff Elementary School
Collector: AS Collect Date: 11/08/2016 12:52 am Sample Type: S

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead < 1.00 µg/L EPA 200.8 1.00 1 11/09/16 RPV 11/14/16 18:46 RPV

Sample Number: 6112160-26 Site: OTF-KC-1F-LIBCOP Sample ID: Frederic A. Priff Elementary School
Collector: AS Collect Date: 11/08/2016 12:56 am Sample Type: S

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead 44.1 µg/L EPA 200.8 1.00 1 11/09/16 RPV 11/14/16 18:50 RPV

Sample Number: 6112160-27 Site: OTF-KC-1F-LIBWORK Sample ID: Frederic A. Priff Elementary School
Collector: AS Collect Date: 11/08/2016 1:00 am Sample Type: S

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead 14.3 µg/L EPA 200.8 1.00 1 11/09/16 RPV 11/14/16 18:52 RPV

Sample Number: 6112160-28 Site: OTF-CS-1F-ROOM28 Sample ID: Frederic A. Priff Elementary School
Collector: AS Collect Date: 11/08/2016 1:03 am Sample Type: S

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead 19.9 µg/L EPA 200.8 1.00 1 11/09/16 RPV 11/14/16 18:54 RPV

Sample Number: 6112160-29 Site: OTF-CS-1F-ROOM27 Sample ID: Frederic A. Priff Elementary School
Collector: AS Collect Date: 11/08/2016 1:06 am Sample Type: S

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead 18.0 µg/L EPA 200.8 1.00 1 11/09/16 RPV 11/14/16 18:56 RPV

Report Generated On: 11/23/2016 4:34 pm 6112160
STL_Results Revision #1.6 Effective: 07/09/2014





SUBURBAN TESTING LABS

Sample Number: 6112160-30 Site: OTF-CS-1F-ROOM20 Sample ID: Frederic A. Priff Elementary School
 Collector: AS Collect Date: 11/08/2016 1:09 am Sample Type: S

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead 15.1 µg/L EPA 200.8 1.00 1 11/09/16 RPV 11/14/16 19:02 RPV

Sample Number: 6112160-31 Site: OTF-DW-1F-ROOM20 Sample ID: Frederic A. Priff Elementary School
 Collector: AS Collect Date: 11/08/2016 1:11 am Sample Type: S

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead < 1.00 µg/L EPA 200.8 1.00 1 11/09/16 RPV 11/14/16 19:03 RPV

Sample Number: 6112160-32 Site: OTF-CS-1F-ROOM7 Sample ID: Frederic A. Priff Elementary School
 Collector: AS Collect Date: 11/08/2016 1:16 am Sample Type: S

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead 5.98 µg/L EPA 200.8 1.00 1 11/09/16 RPV 11/14/16 19:05 RPV

Sample Number: 6112160-33 Site: OTF-DW-1F-ROOM7 Sample ID: Frederic A. Priff Elementary School
 Collector: AS Collect Date: 11/08/2016 1:18 am Sample Type: S

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead < 1.00 µg/L EPA 200.8 1.00 1 11/09/16 RPV 11/14/16 19:07 RPV

Sample Number: 6112160-34 Site: OTF-CS-1F-ROOM21 Sample ID: Frederic A. Priff Elementary School
 Collector: AS Collect Date: 11/08/2016 1:23 am Sample Type: S

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead 4.36 µg/L EPA 200.8 1.00 1 11/09/16 RPV 11/14/16 19:09 RPV

Sample Number: 6112160-35 Site: OTF-DW-1F-ROOM21 Sample ID: Frederic A. Priff Elementary School
 Collector: AS Collect Date: 11/08/2016 1:25 am Sample Type: S

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead < 1.00 µg/L EPA 200.8 1.00 1 11/09/16 RPV 11/14/16 19:15 RPV

Report Generated On: 11/23/2016 4:34 pm 6112160
 STL_Results Revision #1.6 Effective: 07/09/2014





SUBURBAN TESTING LABS

Sample Number: 6112160-36 Site: OTF-CS-1F-ROOM22 Sample ID: Frederic A. Priff Elementary School
 Collector: AS Collect Date: 11/08/2016 1:28 am Sample Type: S

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead 5.16 µg/L EPA 200.8 1.00 1 11/09/16 RPV 11/14/16 19:24 RPV

Sample Number: 6112160-37 Site: OTF-DW-1F-ROOM22 Sample ID: Frederic A. Priff Elementary School
 Collector: AS Collect Date: 11/08/2016 1:30 am Sample Type: S

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead < 1.00 µg/L EPA 200.8 1.00 1 11/09/16 RPV 11/14/16 19:26 RPV

Sample Number: 6112160-38 Site: OTF-CS-1F-ROOM8 Sample ID: Frederic A. Priff Elementary School
 Collector: AS Collect Date: 11/08/2016 1:33 am Sample Type: S

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead 1.86 µg/L EPA 200.8 1.00 1 11/09/16 RPV 11/14/16 19:28 RPV

Sample Number: 6112160-39 Site: OTF-DW-1F-ROOM8 Sample ID: Frederic A. Priff Elementary School
 Collector: AS Collect Date: 11/08/2016 1:35 am Sample Type: S

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead < 1.00 µg/L EPA 200.8 1.00 1 11/09/16 RPV 11/14/16 19:29 RPV

Sample Number: 6112160-40 Site: OTF-CS-1F-ROOM12 Sample ID: Frederic A. Priff Elementary School
 Collector: AS Collect Date: 11/08/2016 1:39 am Sample Type: S

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead 2.06 µg/L EPA 200.8 1.00 1 11/09/16 RPV 11/14/16 19:31 RPV

Sample Number: 6112160-41 Site: OTF-DW-1F-ROOM12 Sample ID: Frederic A. Priff Elementary School
 Collector: AS Collect Date: 11/08/2016 1:41 am Sample Type: S

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead 11.4 µg/L EPA 200.8 1.00 1 11/09/16 RPV 11/14/16 19:33 RPV

Report Generated On: 11/23/2016 4:34 pm 6112160
 STL_Results Revision #1.6 Effective: 07/09/2014





SUBURBAN TESTING LABS

Sample Number: 6112160-42 Site: OTF-CS-1F-ROOM11 Sample ID: Frederic A. Priff Elementary School
 Collector: AS Collect Date: 11/08/2016 1:43 am Sample Type: S

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead 4.69 µg/L EPA 200.8 1.00 1 11/09/16 RPV 11/14/16 19:35 RPV

Sample Number: 6112160-43 Site: OTF-DW-1F-ROOM11 Sample ID: Frederic A. Priff Elementary School
 Collector: AS Collect Date: 11/08/2016 1:45 am Sample Type: S

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead 1.58 µg/L EPA 200.8 1.00 1 11/09/16 RPV 11/14/16 19:37 RPV

Sample Number: 6112160-44 Site: OTF-CS-1F-ROOM23 Sample ID: Frederic A. Priff Elementary School
 Collector: AS Collect Date: 11/08/2016 1:48 am Sample Type: S

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead 1.36 µg/L EPA 200.8 1.00 1 11/09/16 RPV 11/14/16 19:39 RPV

Sample Number: 6112160-45 Site: OTF-DW-1F-ROOM23 Sample ID: Frederic A. Priff Elementary School
 Collector: AS Collect Date: 11/08/2016 1:50 am Sample Type: S

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead < 1.00 µg/L EPA 200.8 1.00 1 11/09/16 RPV 11/14/16 19:47 RPV

Sample Number: 6112160-46 Site: OTF-CS-1F-ROOM9 Sample ID: Frederic A. Priff Elementary School
 Collector: AS Collect Date: 11/08/2016 1:55 am Sample Type: S

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead 1.87 µg/L EPA 200.8 1.00 1 11/09/16 RPV 11/14/16 19:41 RPV

Sample Number: 6112160-47 Site: OTF-DW-1F-ROOM9 Sample ID: Frederic A. Priff Elementary School
 Collector: AS Collect Date: 11/08/2016 1:57 am Sample Type: S

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead < 1.00 µg/L EPA 200.8 1.00 1 11/09/16 RPV 11/14/16 19:50 RPV

Report Generated On: 11/23/2016 4:34 pm 6112160
 STL_Results Revision #1.6 Effective: 07/09/2014





SUBURBAN TESTING LABS

Sample Number: 6112160-48 Site: OTF-CS-1F-ROOM10 Sample ID: Frederic A. Priff Elementary School
 Collector: AS Collect Date: 11/08/2016 2:00 am Sample Type: S

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead 5.70 µg/L EPA 200.8 1.00 1 11/09/16 RPV 11/14/16 19:52 RPV

Sample Number: 6112160-49 Site: OTF-DW-1F-ROOM10 Sample ID: Frederic A. Priff Elementary School
 Collector: AS Collect Date: 11/08/2016 2:02 am Sample Type: S

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead 1.32 µg/L EPA 200.8 1.00 1 11/09/16 RPV 11/14/16 19:54 RPV

Sample Number: 6112160-50 Site: OTF-CS-1F-ROOM25 Sample ID: Frederic A. Priff Elementary School
 Collector: AS Collect Date: 11/08/2016 2:04 am Sample Type: S

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead 5.25 µg/L EPA 200.8 1.00 1 11/09/16 RPV 11/14/16 19:56 RPV

Sample Number: 6112160-51 Site: OTF-DW-1F-ROOM25 Sample ID: Frederic A. Priff Elementary School
 Collector: AS Collect Date: 11/08/2016 2:06 am Sample Type: S

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead < 1.00 µg/L EPA 200.8 1.00 1 11/09/16 RPV 11/14/16 19:58 RPV

Sample Number: 6112160-52 Site: OTF-CS-1F-ROOM24 Sample ID: Frederic A. Priff Elementary School
 Collector: AS Collect Date: 11/08/2016 2:09 am Sample Type: S

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead 1.37 µg/L EPA 200.8 1.00 1 11/09/16 RPV 11/14/16 20:00 RPV

Sample Number: 6112160-53 Site: OTF-DW-1F-ROOM24 Sample ID: Frederic A. Priff Elementary School
 Collector: AS Collect Date: 11/08/2016 2:11 am Sample Type: S

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead < 1.00 µg/L EPA 200.8 1.00 1 11/09/16 RPV 11/14/16 20:02 RPV

Report Generated On: 11/23/2016 4:34 pm 6112160
 STL_Results Revision #1.6 Effective: 07/09/2014





SUBURBAN TESTING LABS

Sample Number: 6112160-54 Site: Laboratory Control Sample-1 Sample ID: Frederic A. Priff Elementary School
 Collector: Collect Date: 11/09/2016 12:00 am Sample Type: S

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead 13.8 µg/L EPA 200.8 1.00 1 11/09/16 RPV 11/14/16 20:04 RPV

Sample Number: 6112160-55 Site: Laboratory Control Sample-2 Sample ID: Frederic A. Priff Elementary School
 Collector: Collect Date: 11/09/2016 12:00 am Sample Type: S

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead 13.9 µg/L EPA 200.8 1.00 1 11/09/16 RPV 11/14/16 20:10 RPV

Sample Number: 6112160-56 Site: Laboratory Control Sample-3 Sample ID: Frederic A. Priff Elementary School
 Collector: Collect Date: 11/09/2016 12:00 am Sample Type: S

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead 13.7 µg/L EPA 200.8 1.00 1 11/09/16 RPV 11/14/16 20:12 RPV

Sample Number: 6112160-57 Site: Laboratory Control Sample-1-Dup Sample ID: Frederic A. Priff Elementary School
 Collector: Collect Date: 11/09/2016 12:00 am Sample Type: S

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead 13.9 µg/L EPA 200.8 1.00 1 11/09/16 RPV 11/14/16 20:14 RPV

Sample Number: 6112160-58 Site: Laboratory Control Sample-2-Dup Sample ID: Frederic A. Priff Elementary School
 Collector: Collect Date: 11/09/2016 12:00 am Sample Type: S

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead 14.0 µg/L EPA 200.8 1.00 1 11/09/16 RPV 11/14/16 20:16 RPV

Sample Number: 6112160-59 Site: Laboratory Control Sample-3-Dup Sample ID: Frederic A. Priff Elementary School
 Collector: Collect Date: 11/09/2016 12:00 am Sample Type: S

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead 13.9 µg/L EPA 200.8 1.00 1 11/09/16 RPV 11/14/16 20:18 RPV

Data Qualifiers:

Report Generated On: 11/23/2016 4:34 pm 6112160
 STL_Results Revision #1.6 Effective: 07/09/2014





Sample Receipt Conditions:

All samples met the sample receipt requirements for the relevant analyses.

All results meet the requirements of STL's TNI (NELAC) Accredited Quality System unless otherwise noted. If your results contain any data qualifiers or comments, you should evaluate useability relative to your needs.

If collectors initials include "STL", samples have been collected in accordance with STL SOP SL0015.

All results reported on an As Received (Wet Weight) basis unless otherwise noted.

This laboratory report may not be reproduced, except in full, without the written approval of STL.

Results are considered Preliminary unless report is signed by authorized representative of STL.

Reviewed and Released By:

William Smith
Technical Director

Report Generated On: 11/23/2016 4:34 pm 6112160
STL_Results Revision #1.6 Effective: 07/09/2014





SUBURBAN TESTING LABS

6112160
Chain of Custody Record
 1037F MacArthur Road, Reading, PA 19605
 610-375-TEST - Fax: 610-375-4090 - suburbantestinglabs.com

TAT(Check One): Standard 24hr 48hr 72hr Other _____
 (Additional charges may apply for rush TAT. If not specified, standard TAT will apply)

Order ID: _____

Client Name: <u>Karl Environmental Group</u> Address: <u>20 Lauck Road</u> Phone: <u>610-856-7700</u> <u>Mohnton, PA 19540</u> Fax: <u>610-856-5040</u> Contact Name: <u>Kelly Mays</u> Email: <u>kmays@karlenv.com</u>	Project Name: <u>Ocean Township School District - Lead in Drinking Water</u> Address: <u>Frederic A. Priff Elementary School</u> <u>139 Wells Mill Road, Waretown, NJ 08758</u> Payment / P.O. Info: <u>16-0811</u>
--	--

Comments:

Hold "FLUSH" samples. Run "FLUSH" sample if corresponding sample lead concentration is 15.5ppb or greater.

SWTL Sample Number	Sample Description / Site ID:	Date Sampled	Time Sampled	Samplers Initials	Test(s) Requested:	Bottle Quantity	See Codes Below				Comments / Field Data:
							Matrix	Sample Type	Bottle Type	Preservative	
	OTF-BLANK	11/7/2016	1132	AS	Lead	1	PW	G	P	NA	Blank
	OTF-SL-1FL-BOILER	11/7/2016	1135	AS	Lead	1	PW	G	P	NA	Service Line
	OTF-CS-1FL-ROOM1	11/7/2016	1138	AS	Lead	1	PW	G	P	NA	Aerator: yes
	OTF-CS-1FL-ROOM2-1	11/7/2016	1141	AS	Lead	1	PW	G	P	NA	Aerator: yes
	OTF-CS-1FL-ROOM2-2	11/7/2016	1144	AS	Lead	1	PW	G	P	NA	↓
	OTF-DW-1FL-GYM1	11/7/2016	1148	AS	Lead	1	PW	G	P	NA	NA
	OTF-DW-1FL-GYM2	11/7/2016	1150	AS	Lead	1	PW	G	P	NA	NA
	OTF-KC-1FL-KITCHEN-1	11/7/2016	1153	AS	Lead	1	PW	G	P	NA	Aerator: yes

Relinquished By: <u>Anthony J. [Signature]</u> Date: <u>11-9-16</u> Time: <u>4:38</u>											
Received By: <u>Kelly Mays</u> Date: <u>11-8-16</u> Time: <u>4:38</u>	Temp °C: _____	Acceptable: Y / N	Sample Conditions Submitted with COC? <input checked="" type="checkbox"/> Y / N Number of containers match number on COC? <input checked="" type="checkbox"/> Y / N All containers in tact? <input checked="" type="checkbox"/> Y / N Tests within holding times <input checked="" type="checkbox"/> Y / N 40 mL VOA vials free of headspace? <input type="checkbox"/> Y / N	Matrix Key NPW = Non-Potable Water Solid = Raw Sludge, Dewatered sludge, soil, etc. (reported as mg/kg) PW = Potable Water (not for SDWA compliance) SDWA = Safe Drinking Water Act Potable Sample	Bottle Type Key P = Plastic G = Glass O = Other	Reporting Options <input type="checkbox"/> SDWA Reporting PWSID: _____ <input type="checkbox"/> Fax <input checked="" type="checkbox"/> Email <input type="checkbox"/> Other _____ <input type="checkbox"/> Return a copy of this form with Report					
Relinquished By: <u>Kelly Mays</u> Date: <u>11-9-16</u> Time: <u>0930</u>	Temp °C: _____	Acceptable: Y / N		Sample Type Key G = Grab BHC = 8 Hr. Composite 24HC = 24 Hr. Composite	SDWA Sample Types D=Distribution E=Entry Point R=Raw C=Check S=Special M=Maximum Residence	Preservative Key N = Sodium Thiosulfate A = Ascorbic Acid H = HNO ₃ C = HCl S = H ₂ SO ₄ OH = NaOH O = Other NA = None Required					
Received in Lab By: <u>[Signature]</u> Date: <u>11/9/16</u> Time: <u>09:30</u>	Temp °C: <u>13.5</u>	Acceptable: <input checked="" type="checkbox"/> Y / N									

Signing this form indicates your agreement with SWTL's Standard Terms and Conditions unless otherwise specified in writing. SLF059 Rev. 1.4 Effective November 12, 2014
 Shaded areas are for SWTL use only.



SUBURBAN TESTING LABS

Chain of Custody Record
 1037F MacArthur Road, Reading, PA 19605
 610-375-TEST - Fax: 610-375-4090 - suburbantestinglabs.com

TAT(Check One): Standard 24hr 48hr 72hr Other _____
 (Additional charges may apply for rush TAT. If not specified, standard TAT will apply)

Order ID: _____

Client Name: <u>Karl Environmental Group</u>	Project Name: <u>Ocean Township School District - Lead in Drinking Water</u>
Address: <u>20 Lauck Road</u> <u>Mohnton, PA 19540</u>	Address: <u>Frederic A. Priff Elementary School</u> <u>139 Wells Mill Road, Waretown, NJ 08758</u>
Phone: <u>610-856-7700</u>	Payment / P.O. Info: <u>16-0811</u>
Fax: <u>610-856-5040</u>	
Contact Name: <u>Kelly Mays</u>	Email: <u>kmays@karlenv.com</u>

Comments:

Hold "FLUSH" samples. Run "FLUSH" sample if corresponding sample lead concentration is 15.5ppb or greater.

SWTL Sample Number	Sample Description / Site ID:	Date Sampled	Time Sampled	Samplers Initials	Test(s) Requested:	Bottle Quantity	See Codes Below				Comments / Field Data:
							Matrix	Sample Type	Bottle Type	Preservative	
	OTF-KC-1FL-KITCHEN-2	11/7/2016	1155	AS	Lead	1	PW	G	P	NA	Aer: yes
	OTF-KC-1FL-KITCHEN-3	11/7/2016	1157	AS	Lead	1	PW	G	P	NA	Aer: yes
	OTF-CV-1FL-KITCHEN-1	11/7/2016		AS	Lead	1	PW	G	P	NA	
	OTF-CV-1FL-KITCHEN-2	11/8/2016	0004 1204	AS	Lead	1	PW	G	P	NA	N/A
	OTF-CS-1FL-ROOM3	11/8/2016	0010 1213	AS	Lead	1	PW	G	P	NA	Aerator: yes
	OTF-DW-1FL-ROOM3	11/8/2016	0012 1212	AS	Lead	1	PW	G	P	NA	NA
	OTF-CS-1FL-ROOM4	11/8/2016	0020 1220	AS	Lead	1	PW	G	P	NA	Aera: yes
	OTF-DW-1FL-ROOM4	11/8/2016	0032 1232	AS	Lead	1	PW	G	P	NA	

Relinquished By: <u>Anthony J. Smith</u>	Date: <u>11-8-16</u>	Time: <u>4:38</u>	Temp °C: _____	Acceptable: Y / N	Sample Conditions	Submitted with COC? <input checked="" type="checkbox"/> Y / N	Matrix Key	NPW = Non-Potable Water Solid = Raw Sludge, Dewatered sludge, soil, etc. (reported as mg/kg) PW = Potable Water (not for SDWA compliance) SDWA = Safe Drinking Water Act Potable Sample	Bottle Type Key	P = Plastic G = Glass O = Other	Reporting Options	<input type="checkbox"/> SDWA Reporting PWSID: _____
Received By: <u>Kelly Mays</u>	Date: <u>11-8-16</u>	Time: <u>4:38</u>	Temp °C: _____	Acceptable: Y / N	Number of containers match number on COC? <input checked="" type="checkbox"/> Y / N	All containers in tact? <input checked="" type="checkbox"/> Y / N	Sample Type Key	G = Grab 8HC = 8 Hr. Composite 24HC = 24 Hr. Composite	Preservative Key	N = Sodium Thiosulfate A = Ascorbic Acid H = HNO ₃ C = HCl S = H ₂ SO ₄ OH = NaOH O = Other NA = None Required	<input type="checkbox"/> Fax <input checked="" type="checkbox"/> Email <input type="checkbox"/> Other _____	<input type="checkbox"/> Return a copy of this form with Report
Relinquished By: <u>Kelly Mays</u>	Date: <u>11-9-16</u>	Time: <u>0930</u>	Temp °C: _____	Acceptable: Y / N	Tests within holding times <input checked="" type="checkbox"/> Y / N	40 mL VOA vials free of headspace? <input type="checkbox"/> Y / N	SDWA Sample Types	D=Distribution E=Entry Point R=Raw C=Check S=Special M=Maximum Residence				
Received in Lab By: <u>Cheryl Ann</u>	Date: <u>11/9/16</u>	Time: <u>09:30</u>	Temp °C: <u>13.5</u>	Acceptable: <input checked="" type="checkbox"/> Y / N								

Signing this form indicates your agreement with SWTL's Standard Terms and Conditions unless otherwise specified in writing. SLF059 Rev. 1.4 Effective November 12, 2014
 Shaded areas are for SWTL use only.



SUBURBAN TESTING LABS

Chain of Custody Record
 1037F MacArthur Road, Reading, PA 19605
 610-375-TEST - Fax: 610-375-4090 - suburbantestinglabs.com

TAT(Check One): Standard 24hr 48hr 72hr Other _____
 (Additional charges may apply for rush TAT. If not specified, standard TAT will apply)

Order ID: _____

Client Name: <u>Karl Environmental Group</u> Address: <u>20 Lauck Road</u> Phone: <u>610-856-7700</u> <u>Mohnton, PA 19540</u> Fax: <u>610-856-5040</u> Contact Name: <u>Kelly Mays</u> Email: <u>kmays@karlenv.com</u>	Project Name: <u>Ocean Township School District - Lead in Drinking Water</u> Address: <u>Frederic A. Priff Elementary School</u> <u>139 Wells Mill Road, Waretown, NJ 08758</u> Payment / P.O. Info: <u>16-0811</u>
--	--

Comments:

Hold "FLUSH" samples. Run "FLUSH" sample if corresponding sample lead concentration is 15.5ppb or greater.

SWTL Sample Number	Sample Description / Site ID:	Date Sampled	Time Sampled	Samplers Initials	Test(s) Requested:	Bottle Quantity	See Codes Below				Comments / Field Data:
							Matrix	Sample Type	Bottle Type	Preservative	
	OTF-NS-1FL-NURSE	11/9/2016	0021 1226	AS	Lead	1	PW	G	P	NA	Aera: yes
	OTF-TL-1FL-FACULTY	11/8/2016	0028 1228	AS	Lead	1	PW	G	P	NA	Aera: yes
	OTF-CS-1FL-ROOM18	11/8/2016	0031 1221	AS	Lead	1	PW	G	P	NA	Aera: yes
	OTF-DW-1FL-ROOM18	11/9/2016	0053 1233	AS	Lead	1	PW	G	P	NA	NA
	OTF-CS-1FL-ROOM5	11/8/2016	0038 1238	AS	Lead	1	PW	G	P	NA	Aera: yes
	OTF-DW-1FL-ROOM5	11/8/2016	0040 1240	AS	Lead	1	PW	G	P	NA	NA
	OTF-CS-1FL-ROOM19	11/8/2016	0045 1245	AS	Lead	1	PW	G	P	NA	Aera: yes
	OTF-DW-1FL-ROOM19	11/8/2016	0047 1247	AS	Lead	1	PW	G	P	NA	NA

Relinquished By: <u>Anthony Smith</u> Date: <u>11-8-16</u> Time: <u>4:38 AM</u>											
Received By: <u>Kelly Mays</u> Date: <u>11-8-16</u> Time: <u>6:38 AM</u> Temp °C: _____ Acceptable: Y / N			Sample Conditions Submitted with COC? <input checked="" type="checkbox"/> Y <input type="checkbox"/> N Number of containers match number on COC? <input checked="" type="checkbox"/> Y <input type="checkbox"/> N All containers in fact? <input checked="" type="checkbox"/> Y <input type="checkbox"/> N Tests within holding times <input checked="" type="checkbox"/> Y <input type="checkbox"/> N 40 mL VOA vials free of headspace? <input type="checkbox"/> Y <input type="checkbox"/> N	Matrix Key NPW = Non-Potable Water Solid = Raw Sludge, Dewatered sludge, soil, etc. (reported as mg/kg) PW = Potable Water (not for SDWA compliance) SDWA = Safe Drinking Water Act Potable Sample	Bottle Type Key P = Plastic G = Glass O = Other Preservative Key N = Sodium Thiosulfate A = Ascorbic Acid H = HNO ₃ C = HCl S = H ₂ SO ₄ OH = NaOH O = Other NA = None Required	Reporting Options <input type="checkbox"/> SDWA Reporting PWSID: _____ <input type="checkbox"/> Fax <input checked="" type="checkbox"/> Email <input type="checkbox"/> Other _____ <input type="checkbox"/> Return a copy of this form with Report					
Relinquished By: <u>Kelly Mays</u> Date: <u>11-9-16</u> Time: <u>0930</u> Temp °C: _____ Acceptable: Y / N					Sample Type Key G = Grab 8HC = 8 Hr. Composite 24HC = 24 Hr. Composite	SDWA Sample Types D=Distribution E=Entry Point R=Raw C=Check S=Special M=Maximum Residence					
Received in Lab By: <u>[Signature]</u> Date: <u>11/9/16</u> Time: <u>09:30</u> Temp °C: <u>13.5</u> Acceptable: <input checked="" type="checkbox"/> Y <input type="checkbox"/> N											

Signing this form indicates your agreement with SWTL's Standard Terms and Conditions unless otherwise specified in writing. SLF059 Rev. 1.4 Effective November 12, 2014
 Shaded areas are for SWTL use only.



SUBURBAN TESTING LABS

Chain of Custody Record
1037F MacArthur Road, Reading, PA 19605
610-375-TEST - Fax: 610-375-4090 - suburbantestinglabs.com

TAT(Check One): Standard 24hr 48hr 72hr Other _____
(Additional charges may apply for rush TAT. If not specified, standard TAT will apply)

Order ID: _____

Client Name: <u>Karl Environmental Group</u>	Project Name: <u>Ocean Township School District - Lead in Drinking Water</u>
Address: <u>20 Lauck Road</u> <u>Mohnton, PA 19540</u>	Address: <u>Frederic A. Priff Elementary School</u> <u>139 Wells Mill Road, Waretown, NJ 08758</u>
Phone: <u>610-856-7700</u> Fax: <u>610-856-5040</u>	Payment / P.O. Info: <u>16-0811</u>
Contact Name: <u>Kelly Mays</u> Email: <u>kmays@karlenv.com</u>	

Comments:

Hold "FLUSH" samples. Run "FLUSH" sample if corresponding sample lead concentration is 15.5ppb or greater.

SWTL Sample Number	Sample Description / Site ID:	Date Sampled	Time Sampled	Samplers Initials	Test(s) Requested:	Bottle Quantity	See Codes Below				Comments / Field Data:
							Matrix	Sample Type	Bottle Type	Preservative	
	OTF-CS-1FL-ROOM6	11/8/2016	0050 1250	AS	Lead	1	PW	G	P	NA	Aera: yes
	OTF-DW-1FL-ROOM6	11/8/2016	0052 1252	AS	Lead	1	PW	G	P	NA	NA
	OTF-KC-1FL-LIBCOP	11/8/2016	0056 1256	AS	Lead	1	PW	G	P	NA	Aera: yes
	OTF-KC-1FL-LIBWORK	11/8/2016	0100 1300	AS	Lead	1	PW	G	P	NA	Aera: yes
	OTF-CS-1FL-ROOM28	11/8/2016	0103 1303	AS	Lead	1	PW	G	P	NA	Aera: yes
	OTF-CS-1FL-ROOM27	11/8/2016	0104 1304	AS	Lead	1	PW	G	P	NA	Aera: yes
	OTF-CS-1FL-ROOM20	11/8/2016	0107 1307	AS	Lead	1	PW	G	P	NA	Aera: yes
	OTF-DW-1FL-ROOM20	11/8/2016	0111 1311	AS	Lead	1	PW	G	P	NA	NA

Relinquished By: <u>Anthony J. [Signature]</u>	Date: <u>11-8-16</u>	Temp °C: _____ Acceptable: Y / N	Submitted with COC? <input checked="" type="checkbox"/> Y / <input type="checkbox"/> N	Matrix Key		Bottle Type Key	Reporting Options
Received By: <u>Kelly Z Mays</u>	Date: <u>11-8-16</u>		Number of containers match number on COC? <input checked="" type="checkbox"/> Y / <input type="checkbox"/> N	NPW = Non-Potable Water Solid = Raw Sludge, Dewatered sludge, soil, etc. (reported as mg/kg)	P = Plastic G = Glass O = Other		
Relinquished By: <u>Kelly Z Mays</u>	Date: <u>11-9-16</u>	Temp °C: _____ Acceptable: Y / N	All containers in tact? <input checked="" type="checkbox"/> Y / <input type="checkbox"/> N	Sample Type Key		Preservative Key	Other: _____
Received in Lab By: <u>Chig [Signature]</u>	Date: <u>11/9/16</u>		Tests within holding times <input checked="" type="checkbox"/> Y / <input type="checkbox"/> N	PW = Potable Water (not for SDWA compliance) SDWA = Safe Drinking Water Act Potable Sample	G = Grab BHC = 8 Hr. Composite 24HC = 24 Hr. Composite		
	Date: <u>11/9/16</u>	Temp °C: <u>13.5</u>	40 mL VOA vials free of headspace? <input type="checkbox"/> Y / <input type="checkbox"/> N	SDWA Sample Types			
	Date: <u>09/13/16</u>	Acceptable: <input checked="" type="checkbox"/> Y / <input type="checkbox"/> N		D=Distribution E=Entry Point R=Raw C=Check S=Special M=Maximum Residence			

Signing this form indicates your agreement with SWTL's Standard Terms and Conditions unless otherwise specified in writing. SLF059 Rev. 1.4 Effective November 12, 2014
Shaded areas are for SWTL use only.



SUBURBAN TESTING LABS

Chain of Custody Record
 1037F MacArthur Road, Reading, PA 19605
 610-375-TEST - Fax: 610-375-4090 - suburbantestinglabs.com

TAT (Check One): Standard 24hr 48hr 72hr Other _____
 (Additional charges may apply for rush TAT. If not specified, standard TAT will apply)

Order ID: _____

Client Name: <u>Karl Environmental Group</u> Address: <u>20 Lauck Road</u> Phone: <u>610-856-7700</u> <u>Mohnton, PA 19540</u> Fax: <u>610-856-5040</u> Contact Name: <u>Kelly Mays</u> Email: <u>kmays@karlenv.com</u>	Project Name: <u>Ocean Township School District - Lead in Drinking Water</u> Address: <u>Frederic A. Priff Elementary School</u> <u>139 Wells Mill Road, Waretown, NJ 08758</u> Payment / P.O. Info: <u>16-0811</u>
--	--

Comments:

Hold "FLUSH" samples. Run "FLUSH" sample if corresponding sample lead concentration is 15.5ppb or greater.

SWTL Sample Number	Sample Description / Site ID:	Date Sampled	Time Sampled	Samplers Initials	Test(s) Requested:	Bottle Quantity	See Codes Below				Comments / Field Data:
							Matrix	Sample Type	Bottle Type	Preservative	
	OTF-CS-1FL-ROOM7	11/8/2016	0116 1316	AS	Lead	1	PW	G	P	NA	Aera: yes
	OTF-DW-1FL-ROOM7	11/9/2016	0118 1318	AS	Lead	1	PW	G	P	NA	NA
	OTF-CS-1FL-ROOM21	11/8/2016	0123 1323	AS	Lead	1	PW	G	P	NA	Aera: yes
	OTF-DW-1FL-ROOM21	11/8/2016	0125 1325	AS	Lead	1	PW	G	P	NA	NA
	OTF-CS-1FL-ROOM22	11/8/2016	0128 1328	AS	Lead	1	PW	G	P	NA	Aera: yes
	OTF-DW-1FL-ROOM22	11/8/2016	0130 1330	AS	Lead	1	PW	G	P	NA	NA
	OTF-CS-1FL-ROOM8	11/8/2016	0133 1333	AS	Lead	1	PW	G	P	NA	Aera: yes
	OTF-DW-1FL-ROOM8	11/8/2016	0135 1335	AS	Lead	1	PW	G	P	NA	NA

Relinquished By: <u>Anthony J. Sant</u> Date: <u>11-8-16</u> Time: <u>4:38</u>	Temp °C: _____ Acceptable: Y / N	Submitted with COC? <input checked="" type="checkbox"/> Y / <input type="checkbox"/> N	Matrix Key NPW = Non-Potable Water Solid = Raw Sludge, Dewatered sludge, soil, etc. (reported as mg/kg) PW = Potable Water (not for SDWA compliance) SDWA = Safe Drinking Water Act Potable Sample	Bottle Type Key P = Plastic G = Glass O = Other Preservative Key N = Sodium Thiosulfate A = Ascorbic Acid H = HNO ₃ C = HCl S = H ₂ SO ₄ OH = NaOH O = Other NA = None Required	Reporting Options <input type="checkbox"/> SDWA Reporting PWSID: _____ <input type="checkbox"/> Fax <input checked="" type="checkbox"/> Email <input type="checkbox"/> Other _____ <input type="checkbox"/> Return a copy of this form with Report
Received By: <u>Kelly Mays</u> Date: <u>11-8-16</u> Time: <u>4:38</u>	Temp °C: _____ Acceptable: Y / N	Number of containers match number on COC? <input checked="" type="checkbox"/> Y / <input type="checkbox"/> N	Sample Type Key G = Grab BHC = 8 Hr. Composite 24HC = 24 Hr. Composite	SDWA Sample Types D = Distribution E = Entry Point R = Raw C = Check S = Special M = Maximum Residence	
Relinquished By: <u>Kelly Mays</u> Date: <u>11-9-16</u> Time: <u>0730</u>	Temp °C: _____ Acceptable: Y / N	All containers in tact? <input checked="" type="checkbox"/> Y / <input type="checkbox"/> N			
Received in Lab By: <u>Cheryl Ann</u> Date: <u>11/9/16</u> Time: <u>0730</u>	Temp °C: <u>13.5</u> Acceptable: <input checked="" type="checkbox"/> Y / <input type="checkbox"/> N	Tests within holding times <input checked="" type="checkbox"/> Y / <input type="checkbox"/> N	40 mL VOA vials free of headspace? <input type="checkbox"/> Y / <input checked="" type="checkbox"/> N		

Signing this form indicates your agreement with SWTL's Standard Terms and Conditions unless otherwise specified in writing. SLF059 Rev. 1.4 Effective November 12, 2014
 Shaded areas are for SWTL use only.



SUBURBAN TESTING LABS

Chain of Custody Record
 1037F MacArthur Road, Reading, PA 19605
 610-375-TEST - Fax: 610-375-4090 - suburbantestinglabs.com

TAT(Check One): Standard 24hr 48hr 72hr Other _____
 (Additional charges may apply for rush TAT. If not specified, standard TAT will apply)

Order ID: _____

Client Name: <u>Karl Environmental Group</u> Address: <u>20 Lauck Road</u> <u>Mohnton, PA 19540</u> Contact Name: <u>Kelly Mays</u>	Project Name: <u>Ocean Township School District - Lead in Drinking Water</u> Address: <u>Frederic A. Priff Elementary School</u> <u>139 Wells Mill Road, Waretown, NJ 08758</u> Payment / P.O. Info: <u>16-0811</u>
Phone: <u>610-856-7700</u> Fax: <u>610-856-5040</u> Email: <u>kmays@karlenv.com</u>	

Comments: Hold "FLUSH" samples. Run "FLUSH" sample if corresponding sample lead concentration is 15.5ppb or greater.

SWTL Sample Number	Sample Description / Site ID:	Date Sampled	Time Sampled	Samplers Initials	Test(s) Requested:	Bottle Quantity	See Codes Below				Comments / Field Data:
							Matrix	Sample Type	Bottle Type	Preservative	
	OTF-CS-1FL-ROOM12	11/8/2016	0137 1337	AS	Lead	1	PW	G	P	NA	Aera: yes
	OTF-DW-1FL-ROOM12	11/8/2016	0141 1341	AS	Lead	1	PW	G	P	NA	NA
	OTF-CS-1FL-ROOM11	11/8/2016	0143 1343	AS	Lead	1	PW	G	P	NA	Aera: yes
	OTF-DW-1FL-ROOM11	11/8/2016	0143 1343	AS	Lead	1	PW	G	P	NA	NA
	OTF-CS-1FL-ROOM23	11/8/2016	0148 1348	AS	Lead	1	PW	G	P	NA	Aera: Removed
	OTF-DW-1FL-ROOM23	11/8/2016	0150 1350	AS	Lead	1	PW	G	P	NA	NA
	OTF-CS-1FL-ROOM9	11/8/2016	0152 1352	AS	Lead	1	PW	G	P	NA	Aera: No
	OTF-DW-1FL-ROOM9	11/8/2016	0157 1357	AS	Lead	1	PW	G	P	NA	NA

Relinquished By: <u>Anthony J. Dant</u> Date: <u>11-8-16</u> Time: <u>4:38</u>	Temp °C: _____ Acceptable: Y / N	Submitted with COC? <input checked="" type="checkbox"/> Y / N	Matrix Key NPW = Non-Potable Water Solid = Raw Sludge, Dewatered sludge, soil, etc. (reported as mg/kg) PW = Potable Water (not for SDWA compliance) SDWA = Safe Drinking Water Act Potable Sample	Bottle Type Key P = Plastic G = Glass O = Other	Reporting Options <input type="checkbox"/> SDWA Reporting PWSID: _____ <input type="checkbox"/> Fax <input checked="" type="checkbox"/> Email <input type="checkbox"/> Other _____ <input type="checkbox"/> Return a copy of this form with Report
Received By: <u>Kelly Mays</u> Date: <u>11-8-16</u> Time: <u>4:38</u>	Temp °C: _____ Acceptable: Y / N	Number of containers match number on COC? <input checked="" type="checkbox"/> Y / N	Sample Type Key G = Grab 8HC = 8 Hr. Composite 24HC = 24 Hr. Composite	Preservative Key N = Sodium Thiosulfate A = Ascorbic Acid H = HNO ₃ C = HCl S = H ₂ SO ₄ OH = NaOH O = Other NA = None Required	
Relinquished By: <u>Kelly Mays</u> Date: <u>11-9-16</u> Time: <u>0930</u>	Temp °C: _____ Acceptable: Y / N	All containers in tact? <input checked="" type="checkbox"/> Y / N	SDWA Sample Types D = Distribution E = Entry Point R = Raw C = Check S = Special M = Maximum Residence		
Received in Lab By: <u>Christina</u> Date: <u>11/9/16</u> Time: <u>09:30</u>	Temp °C: <u>13.5</u> Acceptable: <input checked="" type="checkbox"/> Y / N	Tests within holding times <input checked="" type="checkbox"/> Y / N			
		40 mL VOA vials free of headspace? Y / N			

Signing this form indicates your agreement with SWTL's Standard Terms and Conditions unless otherwise specified in writing. SLF059 Rev. 1.4 Effective November 12, 2014
 Shaded areas are for SWTL use only.



Chain of Custody Record
 1037F MacArthur Road, Reading, PA 19605
 610-375-TEST - Fax: 610-375-4090 - suburbantestinglabs.com

TAT (Check One): Standard 24hr 48hr 72hr Other _____
 (Additional charges may apply for rush TAT. If not specified, standard TAT will apply)

Order ID: _____

Client Name: <u>Karl Environmental Group</u> Address: <u>20 Lauck Road</u> Phone: <u>610-856-7700</u> <u>Mohnton, PA 19540</u> Fax: <u>610-856-5040</u> Contact Name: <u>Kelly Mays</u> Email: <u>kmays@karlenv.com</u>	Project Name: <u>Ocean Township School District - Lead in Drinking Water</u> Address: <u>Frederic A. Priff Elementary School</u> <u>139 Wells Mill Road, Waretown, NJ 08758</u> Payment / P.O. Info: <u>16-0811</u>
--	--

Comments:

Hold "FLUSH" samples. Run "FLUSH" sample if corresponding sample lead concentration is 15.5ppb or greater.

SWTL Sample Number	Sample Description / Site ID:	Date Sampled	Time Sampled	Samplers Initials	Test(s) Requested:	Bottle Quantity	See Codes Below				Comments / Field Data:
							Matrix	Sample Type	Bottle Type	Preservative	
	OTF-CS-1FL-ROOM10	11/8/2016	0200 1400	AS	Lead	1	PW	G	P	NA	Acra: No
	OTF-DW-1FL-ROOM10	11/8/2016	0202 1402	AS	Lead	1	PW	G	P	NA	NA
	OTF-CS-1FL-ROOM25	11/8/2016	0204 1404	AS	Lead	1	PW	G	P	NA	Acra: yes
	OTF-DW-1FL-ROOM25	11/8/2016	0206 1406	AS	Lead	1	PW	G	P	NA	NA
	OTF-CS-1FL-ROOM24	11/8/2016	0207 1407	AS	Lead	1	PW	G	P	NA	Acra: No
	OTF-DW-1FL-ROOM24	11/8/2016	0211 1411	AS	Lead	1	PW	G	P	NA	NA

Relinquished By: <u>[Signature]</u> Date: <u>11-8-16</u> Time: <u>4:38</u>		Temp °C: _____ Acceptable: Y / N	Submitted with COC? <input type="radio"/> Y / <input checked="" type="radio"/> N	Matrix Key NPW = Non-Potable Water Solid = Raw Sludge, Dewatered sludge, soil, etc. (reported as mg/kg) PW = Potable Water (not for SDWA compliance) SDWA = Safe Drinking Water Act Potable Sample	Bottle Type Key P = Plastic G = Glass O = Other	Reporting Options <input type="checkbox"/> SDWA Reporting PWSID: _____ <input type="checkbox"/> Fax <input checked="" type="checkbox"/> Email <input type="checkbox"/> Other _____ <input type="checkbox"/> Return a copy of this form with Report
Received By: <u>Kelly Mays</u> Date: <u>11-8-16</u> Time: <u>4:38</u>		Temp °C: _____ Acceptable: Y / N	Number of containers match number on COC? <input checked="" type="radio"/> Y / <input type="radio"/> N	Sample Type Key G = Grab BHC = 8 Hr. Composite 24HC = 24 Hr. Composite	Preservative Key N = Sodium Thiosulfate A = Ascorbic Acid H = HNO ₃ C = HCl S = H ₂ SO ₄ OH = NaOH O = Other NA = None Required	
Relinquished By: <u>Kelly Mays</u> Date: <u>11-9-16</u> Time: <u>0930</u>		Temp °C: _____ Acceptable: Y / N	All containers in tact? <input checked="" type="radio"/> Y / <input type="radio"/> N	SDWA Sample Types D = Distribution E = Entry Point R = Raw C = Check S = Special M = Maximum Residence		
Received in Lab By: <u>[Signature]</u> Date: <u>11/9/16</u> Time: <u>04:30</u>		Temp °C: <u>15.3</u> Acceptable: <input checked="" type="radio"/> Y / <input type="radio"/> N	Tests within holding times? <input checked="" type="radio"/> Y / <input type="radio"/> N			
		Temp °C: _____ Acceptable: _____	40 mL VOA vials free of headspace? <input type="radio"/> Y / <input checked="" type="radio"/> N			

Signing this form indicates your agreement with SWTL's Standard Terms and Conditions unless otherwise specified in writing. SLF059 Rev. 1.4 Effective November 12, 2014
 Shaded areas are for SWTL use only.